SIEMENS

Data sheet



SIRIUS motor starter M200D AS-i Communication: AS-Interface DOL starter Standard Electronic switching AC-3, 0.75KW / 400 V 0.15 A...2.00 A Electronic overload protection Thermistor: THERMOCLICK / PTC with brake contact 180 V DC 4 DI / 1 DO AS-i Han Q4/2 - Han Q8/0 with manual on-site operation and keyoperated switch

| product brand name | SIRIUS |
|--|--|
| product designation | Motor starters |
| design of the product | direct starter |
| product type designation | M200D |
| product function | |
| • on-site operation | Yes |
| control circuit interface to parallel wiring | No |
| insulation voltage rated value | 500 V |
| degree of pollution | 3 |
| surge voltage resistance rated value | 6 000 V |
| maximum permissible voltage for protective separation | |
| between main and auxiliary circuit | 400 V |
| between control and auxiliary circuit | 24 V |
| protection class IP | IP65 |
| shock resistance | 12g / 11 ms |
| type of assignment | 1 |
| certificate of suitability | CE |
| Substance Prohibitance (Date) | 07/01/2006 |
| SVHC substance name | Blei - 7439-92-1 Bleimonoxid (Bleioxid) - 1317-36-8 2,2',6,6'-Tetrabrom-4,4'-isopropylidendi - 79-94-7 |
| product function | |
| direct start | Yes |
| reverse starting | No |
| product component motor brake output | Yes |
| product feature | |
| brake control with 230 V AC | No |
| brake control with 400 V AC | No |
| brake control with 24 V DC | No |
| brake control with 180 V DC | Yes |
| brake control with 500 V DC | No |
| product extension braking module for brake control | No |
| product function short circuit protection | Yes |
| design of short-circuit protection | circuit-breakers |
| maximum short-circuit current breaking capacity (Icu) | |
| • at 400 V rated value | 50 000 A |
| at 500 V rated value | 20 000 A |
| EMC emitted interference according to IEC 60947-1 | CISPR11, ambience A (group 2) |
| EMC immunity according to IEC 60947-1 | corresponds to degree of severity 3, ambience A (industrial sector) |
| conducted interference | |
| due to burst according to IEC 61000-4-4 | 2 kV network connection / 1 kV control connection |

| a due to conductor code curre constitue to IFO 04000 4.5 | 2 IW |
|---|------------------------------------|
| due to conductor-earth surge according to IEC 61000-4-5 due to conductor conductor according to IEC. | 2 kV |
| due to conductor-conductor surge according to IEC 61000-4-5 | 1 kV |
| touch protection against electrical shock | finger-safe |
| Main circuit | |
| number of poles for main current circuit | 3 |
| design of the switching contact | solid-state / thyristor / 2 phases |
| adjustable current response value current of the current- dependent overload release | 0.15 2 A |
| type of the motor protection | full motor protection |
| operating voltage rated value | 200 440 V |
| operational current | |
| at AC at 400 V rated value | 2 A |
| at AC-3 at 400 V rated value | 2 A |
| operating power | |
| • at AC-3 | |
| — at 400 V rated value | 0.75 kW |
| — at 500 V rated value | 750 W |
| • at AC-3e | |
| — at 400 V rated value | 1 kW |
| — at 500 V rated value | 0.75 kW |
| product function | |
| digital inputs parameterizable | Yes |
| digital supputs parameterizable | Yes |
| number of digital inputs | 4 |
| number of sockets | |
| for digital output signals | 1 |
| for digital output signals | 4 |
| number of digital outputs | 1 |
| Supply voltage | |
| type of voltage of the supply voltage | DC |
| supply voltage 1 at DC | 24 V |
| supply voltage 1 at DC rated value | 30 V |
| minimum permissible | 26.5 V |
| maximum permissible | 31.6 V |
| Control circuit/ Control | |
| type of voltage of the control supply voltage | DC |
| control supply voltage at DC rated value | 20.4 28.8 V |
| control supply voltage 1 | |
| at DC rated value | 24 V |
| at DC rated value | 20.4 28.8 V |
| • at DC | 20.4 28.8 V |
| control current at DC | |
| in standby mode of operation | 100 mA |
| during operation | 600 mA |
| power loss [W] in auxiliary and control circuit | |
| in switching state OFF with bypass circuit | 1.9872 W |
| in switching state ON with bypass circuit | 2.2176 W |
| Response times | |
| ON-delay time | 25 ms |
| OFF-delay time | 35 ms |
| mounting position | vertical, horizontal, flat |
| • recommended | horizontal |
| fastening method | screw fixing |
| height | 215 mm |
| width | 294 mm |
| depth | 159 mm |
| Ambient conditions | 100 11111 |
| | 2 000 m |
| installation altitude at height above sea level maximum ambient temperature | 2 000 111 |
| amplent temperature | |
| during operation | -25 +55 °C |

| during storage | -40 +70 °C |
|--|---------------------------------------|
| during transport | -40 +70 °C |
| relative humidity during operation | 10 95 % |
| protocol is supported | |
| PROFIBUS DP protocol | No |
| PROFINET protocol | No |
| design of the interface | |
| AS-Interface protocol | Yes |
| PROFINET protocol | No |
| PROFIBUS DP protocol | No |
| product function bus communication | Yes |
| protocol is supported AS-Interface protocol | Yes |
| product function control circuit interface with IO link | No |
| type of electrical connection of the communication interface | M12 plug |
| type of electrical connection | |
| for main current circuit | plug according to ISO 23570, HAN Q4/2 |
| for auxiliary and control circuit | connector |
| type of electrical connection | |
| 1 for digital input signals | M12 socket |
| 1 for digital output signals | M12 socket |
| 2 for digital input signals | M12 socket |
| 3 for digital input signals | M12 socket |
| 4 for digital input signals | M12 socket |
| type of electrical connection | |
| • at the manufacturer-specific device interface | optical interface |
| for device addressing | M12 plug |
| for supply voltage line-side | M12 plug |
| full-load current (FLA) for 3-phase AC motor at 480 V rated value | 1.6 A |
| yielded mechanical performance [hp] | |
| • for 3-phase AC motor | |
| — at 460/480 V rated value | 0.7 hp |
| operating voltage at AC at 60 Hz according to CSA and UL rated value | 480 V |
| Certificates/ approvals | |

General Product Approval

EMC



Confirmation









Declaration of Conformity

Test Certificates

other





Type Test Certificates/Test Report



Confirmation

Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10


Industry Mall (Online ordering system)


https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3RK1325-6KS71-2AA5


Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RK1325-6KS71-2AA5

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)







last modified: 8/9/2023 🖸