## SIEMENS

## Data sheet

## 3RK1395-6KS41-2AD0





SIRIUS motor starter M200D Technology module DOL starter Mechanical switching AC-3, 0.75KW / 400 V 0.15 A...2.00 A Electronic overload protection Thermistor: THERMOCLICK / PTC without brake contact 4 DI / 2 DO Han Q4/2 - Han Q8/0 with manual on-site operation and key-operated switch via communication module 3RK1305\* can be used on PROFIBUS or PROFINET


| product brand name  | SIRIUS   |
|---|--|
| product designation   | Motor starters   |
| design of the product   | direct starter   |
| product type designation  | M200D  |
| product function  |  |
| <ul> <li>on-site operation</li> </ul>   | Yes  |
| <ul> <li>control circuit interface to parallel wiring</li> </ul>  | No   |
| insulation voltage rated value  | 500 V  |
| degree of pollution   | 3  |
| surge voltage resistance rated value  | 6 000 V  |
| maximum permissible voltage for protective separation   |  |
| <ul> <li>between main and auxiliary circuit</li> </ul>  | 400 V  |
| <ul> <li>between control and auxiliary circuit</li> </ul>   | 24 V   |
| protection class IP   | IP65   |
| shock resistance  | 12g / 11 ms  |
| mechanical service life (operating cycles) of the main contacts typical   | 10 000 000   |
| type of assignment  | 2  |
| certificate of suitability  | CE   |
| Substance Prohibitance (Date)   | 07/01/2006   |
| SVHC substance name   | Blei - 7439-92-1<br>Bleimonoxid (Bleioxid) - 1317-36-8<br>2,2',6,6'-Tetrabrom-4,4'-isopropylidendi - 79-94-7 |
| product function  |  |
| direct start  | Yes  |
| reverse starting  | No   |
| product component motor brake output  | No   |
| product feature   |  |
| <ul> <li>brake control with 230 V AC</li> </ul>   | No   |
|   |  |
| <ul> <li>brake control with 400 V AC</li> </ul>   | No   |
| <ul> <li>brake control with 400 V AC</li> <li>brake control with 24 V DC</li> </ul>   | No   |
|   |  |
| • brake control with 24 V DC  | No   |
| <ul><li>brake control with 24 V DC</li><li>brake control with 180 V DC</li></ul>  | No   |
| <ul> <li>brake control with 24 V DC</li> <li>brake control with 180 V DC</li> <li>brake control with 500 V DC</li> </ul>  | No<br>No<br>No   |
| <ul> <li>brake control with 24 V DC</li> <li>brake control with 180 V DC</li> <li>brake control with 500 V DC</li> </ul> product extension braking module for brake control   | No<br>No<br>No   |
| brake control with 24 V DC     brake control with 180 V DC     brake control with 500 V DC     product extension braking module for brake control     product function short circuit protection   | No<br>No<br>No<br>Yes  |
| brake control with 24 V DC     brake control with 180 V DC     brake control with 500 V DC  product extension braking module for brake control  product function short circuit protection  design of short-circuit protection   | No<br>No<br>No<br>Yes  |
| brake control with 24 V DC     brake control with 180 V DC     brake control with 500 V DC  product extension braking module for brake control  product function short circuit protection  design of short-circuit protection  maximum short-circuit current breaking capacity (Icu)  | No<br>No<br>No<br>Yes<br>circuit-breakers  |
| <ul> <li>brake control with 24 V DC</li> <li>brake control with 180 V DC</li> <li>brake control with 500 V DC</li> </ul> product extension braking module for brake control product function short circuit protection design of short-circuit protection maximum short-circuit current breaking capacity (Icu) <ul> <li>at 400 V rated value</li> </ul> | No<br>No<br>No<br>Yes<br>circuit-breakers<br>50 000 A  |
| brake control with 24 V DC     brake control with 180 V DC     brake control with 500 V DC  product extension braking module for brake control product function short circuit protection design of short-circuit protection maximum short-circuit current breaking capacity (Icu)     at 400 V rated value     at 500 V rated value                     | No<br>No<br>No<br>Yes<br>circuit-breakers<br>50 000 A<br>50 000 A  |

| conducted interference  |   |
|---|---|
| due to burst according to IEC 61000-4-4   | 2 kV network connection / 1 kV control connection   |
| <ul> <li>due to conductor-earth surge according to IEC 61000-4-5</li> </ul>   | 2 kV  |
| due to conductor conductor surge according to IEC   | 1 kV  |
| 61000-4-5   |   |
| touch protection against electrical shock   | finger-safe   |
| Main circuit  |   |
| number of poles for main current circuit  | 3   |
| design of the switching contact   | electromechanical   |
| adjustable current response value current of the current-<br>dependent overload release   | 0.15 2 A  |
| type of the motor protection  | full motor protection   |
| operating voltage rated value   | 200 440 V   |
| operational current   | 200 110 V   |
| at AC at 400 V rated value  | 2 A   |
| at AC-3 at 400 V rated value  | 2 A   |
| operating power   |   |
| • at AC-3   |   |
| — at 400 V rated value  | 0.75 kW   |
| — at 500 V rated value  | 750 W   |
| ● at AC-3e  |   |
| — at 400 V rated value  | 1 kW  |
| — at 500 V rated value  | 0.75 kW   |
| product function  |   |
| <ul> <li>digital inputs parameterizable</li> </ul>  | Yes   |
| <ul> <li>digital outputs parameterizable</li> </ul>   | Yes   |
| number of digital inputs  | 4   |
| number of sockets   |   |
| <ul> <li>for digital output signals</li> </ul>  | 2   |
| <ul> <li>for digital input signals</li> </ul>   | 4   |
| number of digital outputs   | 2   |
| Supply voltage  |   |
| type of voltage of the supply voltage   | DC  |
| supply voltage 1 at DC  | 24 V  |
| Control circuit/ Control  | 20  |
| type of voltage of the control supply voltage   | DC  |
| control supply voltage 1  | 20.4 20.0 \/  |
| <ul> <li>at DC rated value</li> <li>at DC</li> </ul>  | 20.4 28.8 V<br>20.4 28.8 V  |
| control current at DC   | 20.4 20.0 V   |
| • in standby mode of operation  | 100 mA  |
| during operation  | 600 mA  |
| power loss [W] in auxiliary and control circuit   |   |
| • in switching state OFF with bypass circuit  | 1.9584 W  |
| in switching state ON with bypass circuit   | 5.04 W  |
| Response times  |   |
| ON-delay time   | 85 ms   |
| OFF-delay time  |   |
| mounting position   | 65 ms   |
|   | 65 ms<br>vertical, horizontal, flat   |
| <ul> <li>recommended</li> </ul>   |   |
| • recommended fastening method  | vertical, horizontal, flat  |
|   | vertical, horizontal, flat<br>horizontal  |
| fastening method  | vertical, horizontal, flat<br>horizontal<br>screw fixing  |
| fastening method<br>height  | vertical, horizontal, flat<br>horizontal<br>screw fixing<br>215 mm  |
| fastening method<br>height<br>width   | vertical, horizontal, flat<br>horizontal<br>screw fixing<br>215 mm<br>294 mm                                    |
| fastening method<br>height<br>width<br>depth  | vertical, horizontal, flat<br>horizontal<br>screw fixing<br>215 mm<br>294 mm                                    |
| fastening method<br>height<br>width<br>depth<br>Ambient conditions  | vertical, horizontal, flat<br>horizontal<br>screw fixing<br>215 mm<br>294 mm<br>148 mm                          |
| fastening method         height         width         depth         Ambient conditions         installation altitude at height above sea level maximum  | vertical, horizontal, flat<br>horizontal<br>screw fixing<br>215 mm<br>294 mm<br>148 mm                          |
| fastening method         height         width         depth         Ambient conditions         installation altitude at height above sea level maximum         ambient temperature                            | vertical, horizontal, flat<br>horizontal<br>screw fixing<br>215 mm<br>294 mm<br>148 mm<br>2 000 m               |
| fastening method         height         width         depth         Ambient conditions         installation altitude at height above sea level maximum         ambient temperature         • during operation | vertical, horizontal, flat<br>horizontal<br>screw fixing<br>215 mm<br>294 mm<br>148 mm<br>2 000 m<br>-25 +55 °C |

| protocol is supported   |  |  |                        |                   |  |
|---|--|--|------------------------|-------------------|--|
| <ul> <li>PROFIBUS DP protocol</li> </ul>  |  | No   |                        |                   |  |
| PROFINET protocol   |  | No   |                        |                   |  |
| design of the interface   |  |  |                        |                   |  |
| <ul> <li>AS-Interface protocol</li> </ul>   |  | No   |                        |                   |  |
| <ul> <li>PROFINET protocol</li> </ul>   |  | No   |                        |                   |  |
| PROFIBUS DP protocol  |  | No   |                        |                   |  |
| product function bus communication  |  | Yes  |                        |                   |  |
| protocol is supported AS-Interface protocol   |  | No   |                        |                   |  |
| product function control circuit interface with IO link   |  | No   |                        |                   |  |
| type of electrical connection   |  |  |                        |                   |  |
| for main current circuit  |  | plug according to ISO 23570, HAN Q4/2  |                        |                   |  |
| <ul> <li>for auxiliary and control circuit</li> </ul>   |  | connector  |                        |                   |  |
| type of electrical connection   |  |  |                        |                   |  |
| <ul> <li>1 for digital input signals</li> </ul>   |  | M12 socket   |                        |                   |  |
| <ul> <li>1 for digital output signals</li> </ul>  |  | M12 socket   |                        |                   |  |
| • 2 for digital input signals   |  | M12 socket   |                        |                   |  |
| • 3 for digital input signals   |  | M12 socket   |                        |                   |  |
| • 4 for digital input signals   |  | M12 socket   |                        |                   |  |
| ull-load current (FLA) for 3-phase AC motor at 4<br>value   | 480 V rated  | 1.6 A  |                        |                   |  |
| yielded mechanical performance [hp]   |  |  |                        |                   |  |
| <ul> <li>for 3-phase AC motor</li> </ul>  |  |  |                        |                   |  |
| — at 460/480 V rated value  |  | 0.7 hp   |                        |                   |  |
| — at 575/600 V rated value  |  | 1 hp   |                        |                   |  |
| operating voltage at AC at 60 Hz according to C<br>rated value  | SA and UL  | 600 V  |                        |                   |  |
| rtificates/ approvals   |  |  |                        |                   |  |
|   | Ĩ  |  | rnr                    | емс               |  |
| General Product Approval  |  | (U)<br>u   | EAC                    | EMC<br>RCM        |  |
| General Product Approval  | CCC<br>Test Certificates   | o other  | EAC                    | EMC<br>EMC<br>RCM |  |
| General Product Approval Confirmation Confirmation Declaration of Conformity  | Test Certificates  | ic- <u>Confirmation</u>  | EAC                    | RCM               |  |
| General Product Approval Confirmation Confirmation Declaration of Conformity CCCUC  | Type Test Certin   | ic- <u>Confirmation</u>  | EAC                    | RCM               |  |
| General Product Approval         Confirmation         Confirmation         Declaration of Conformity  | Type Test Certin   | ic- <u>Confirmation</u>  | <b>ERC</b><br>Profibus | RCM               |  |
| General Product Approval Confirmation Confirmation Declaration of Conformity CCCUC  | Type Test Certin   | ic- <u>Confirmation</u>  | haaan                  | RCM               |  |
| General Product Approval Confirmation Confirmation Declaration of Conformity CCCUC  | Type Test Certin   | ic- <u>Confirmation</u>  | haaan                  | RCM               |  |
| General Product Approval         Confirmation         Confirmation         Declaration of Conformity         CEGE         EG-Konf.  | Type Test Certin   | ic- <u>Confirmation</u>  | haaan                  | RCM               |  |
| General Product Approval         Confirmation         Declaration of Conformity         CEGE         UKE         EG-Konf.         Wither information         Siemens has decided to exit the Russian mail   | <u>Type Test Certi</u><br><u>ates/Test Repo</u><br>rket (see here).  | ic- <u>Confirmation</u><br>rt  | haaan                  | RCM               |  |
| General Product Approval         Confirmation         Declaration of Conformity         CEGE         EG-Konf.         Urther information         Silemens has decided to exit the Russian maintips://press.siemens.com/global/en/pressrelease   | <u>Type Test Certi</u><br><u>ates/Test Repo</u><br>rket (see here).<br>se/siemens-wind-dov   | ic- Confirmation<br>rt<br>/n-russian-business  | haaan                  | RCM               |  |
| General Product Approval         Confirmation         Declaration of Conformity         CE         EG-Konf.         Unter information         Silemens has decided to exit the Russian maintips://press.siemens.com/global/en/pressrelears         Silemens is working on the renewal of the curplease contact your local Siemens office on the   | Type Test Certii<br>ates/Test Repo<br>rket (see here).<br>se/siemens-wind-dow<br>rrent EAC certificat<br>status of validity of tl  | ic- Confirmation<br>rt<br>/n-russian-business<br>es.<br>he EAC certification if you inten-   | Profibus               | Dangerous Good    |  |
| General Product Approval         Confirmation         Declaration of Conformity         Confirmation         EG-Konf.         Wither information         Siemens has decided to exit the Russian maintips://press.siemens.com/global/en/pressreleads         Siemens is working on the renewal of the cuu         Please contact your local Siemens office on the EAC relevant market (other than the sanctioned  | Type Test Certii<br>ates/Test Repo<br>rket (see here).<br>se/siemens-wind-dow<br>rrent EAC certificat<br>status of validity of tl  | ic- Confirmation<br>rt<br>/n-russian-business<br>es.<br>he EAC certification if you inten-   | Profibus               | Dangerous Good    |  |
| General Product Approval         Confirmation         Declaration of Conformity         Certain Conformity         Cerain Conformity   | Type Test Certii<br>ates/Test Report<br>rket (see here).<br>se/siemens-wind-dow<br>rrent EAC certificat<br>status of validity of tl<br>EAEU member state   | ic- Confirmation<br>rt<br>/n-russian-business<br>es.<br>he EAC certification if you inten-   | Profibus               | Dangerous Good    |  |
| General Product Approval         Confirmation         Declaration of Conformity         Confirmation         Bit Section         Siemens has decided to exit the Russian maintips://press.siemens.com/global/en/pressreleas         Siemens is working on the renewal of the current process of the section of the current sec | Type Test Certii<br>ates/Test Repo<br>rket (see here).<br>se/siemens-wind-dow<br>rrent EAC certificat<br>status of validity of tl<br>EAEU member state<br>view/109813875   | ic- Confirmation<br>rt<br>/n-russian-business<br>es.<br>he EAC certification if you inten-   | Profibus               | Dangerous Good    |  |
| General Product Approval         Confirmation         Confirmation         Declaration of Conformity         Confirmation         Confirmation         Understand         Confirmation   | Type Test Certii<br>ates/Test Repo<br>rket (see here).<br>se/siemens-wind-dow<br>rrent EAC certificat<br>status of validity of tl<br>EAEU member state<br>view/109813875   | ic- Confirmation<br>rt<br>/n-russian-business<br>es.<br>he EAC certification if you inten-   | Profibus               | Dangerous Good    |  |
| General Product Approval         Confirmation         Confirmation         Declaration of Conformity         CECE         EGE         EGE </td <td>Type Test Certin<br/>ates/Test Report<br/>rket (see here).<br/>se/siemens-wind-dow<br/>rrent EAC certificat<br/>status of validity of tl<br/>I EAEU member state<br/>view/109813875<br/>Brochures,)</td> <td>ic-<br/>rt<br/><u>/n-russian-business</u><br/>es.<br/>ne EAC certification if you inten-<br/>es Russia or Belarus).</td> <td>Profibus</td> <td>Dangerous Good</td>  | Type Test Certin<br>ates/Test Report<br>rket (see here).<br>se/siemens-wind-dow<br>rrent EAC certificat<br>status of validity of tl<br>I EAEU member state<br>view/109813875<br>Brochures,)                                    | ic-<br>rt<br><u>/n-russian-business</u><br>es.<br>ne EAC certification if you inten-<br>es Russia or Belarus).   | Profibus               | Dangerous Good    |  |
| General Product Approval         Confirmation         Confirmation         Declaration of Conformity         CE         EGE         EGE <td>Type Test Certif<br/>ates/Test Report<br/>rket (see here).<br/>se/siemens-wind-dow<br/>rrent EAC certificat<br/>status of validity of ti<br/>I EAEU member state<br/>view/109813875<br/>Brochures,)</td> <td>ic-<br/>Confirmation<br/>rt<br/>rn-russian-business<br/>as.<br/>as.<br/>BEAC certification if you inten-<br/>s Russia or Belarus).<br/>BRK1395-6KS41-2AD0</td> <td>Profibus</td> <td>Dangerous Good</td>   | Type Test Certif<br>ates/Test Report<br>rket (see here).<br>se/siemens-wind-dow<br>rrent EAC certificat<br>status of validity of ti<br>I EAEU member state<br>view/109813875<br>Brochures,)                                    | ic-<br>Confirmation<br>rt<br>rn-russian-business<br>as.<br>as.<br>BEAC certification if you inten-<br>s Russia or Belarus).<br>BRK1395-6KS41-2AD0                              | Profibus               | Dangerous Good    |  |
| General Product Approval         Confirmation         Confirmation         Declaration of Conformity         Confirmation         Confirmation         Confirmation         Siemens has decided to exit the Russian maintips://press.siemens.com/global/en/pressreleas         Siemens is working on the renewal of the curplease contact your local Siemens office on the EAC relevant market (other than the sanctioned information on the packaging intips://support.industry.siemens.com/cs/ww/en/information- and Downloadcenter (Catalogs,  | Type Test Certii<br>ates/Test Report<br>status of validity of the<br>status of validity of the<br>EAEU member state<br>view/109813875<br>Brochures,)<br>atalog/product?mlfb=:<br>Xorder/default.aspx?<br>practeristics, FAQs,. | ic- Confirmation<br>It<br>In-russian-business<br>es.<br>the EAC certification if you inten-<br>the Russia or Belarus).<br>BRK1395-6KS41-2AD0<br>lang=en&mlfb=3RK1395-6KS4<br>) | Profibus               | Dangerous Good    |  |







last modified:

8/9/2023 🖸