SIEMENS

Data sheet

3SU1802-0AC10-4HB1



AS-Interface enclosure for command devices, 22 mm, round, Enclosure material plastic, enclosure top part gray, 2 control points plastic, Recess for labels, B=Pushbutton white, label: I, 1 NO, spring-type terminal, A=Pushbutton black label: O 1 NC, spring-type terminal, floor mounting, Insulation displacement system on top, Labels enclosed

www.du.et.hvev.ed.weve.e	
product brand name	SIRIUS ACT
product designation	Enclosures
product type designation	3SU1
equipment of commanding and signaling device	A = Pushbutton / B = Pushbutton
manufacturer's article number	
 of supplied contact module 	A1 = 3SU1400-2AA10-3CA0 / B2 = 3SU1400-2AA10-3BA0
 of supplied contact module at the command point A 1 	<u>3SU1400-2AA10-3CA0</u>
 of supplied contact module at the command point B 2 	<u>3SU1400-2AA10-3BA0</u>
 of supplied communication module 	AB = 3SU1400-2EK10-6AA0
 of the supplied holder 	A = 3SU1500-0AA10-0AA0, B = 3SU1500-0AA10-0AA0
 of the supplied holder at the command point A 	<u>3SU1500-0AA10-0AA0</u>
 of the supplied holder at the command point B 	<u>3SU1500-0AA10-0AA0</u>
 of the supplied actuator 	A = 3SU1000-0AB10-0AA0 / B = 3SU1000-0AB60-0AA0
 of the supplied actuator at the command point A 	<u>3SU1000-0AB10-0AA0</u>
 of the supplied actuator at the command point B 	<u>3SU1000-0AB60-0AA0</u>
 of supplied empty enclosure 	<u>3SU1802-0AA00-0AB1</u>
 of supplied accessory 	A = 3SU1900-0AF16-0QA0, B = 3SU1900-0AF16-0QB0
 of the supplied accessories at the command point A 	<u>3SU1900-0AF16-0QA0</u>
 of the supplied accessories at the command point B 	<u>3SU1900-0AF16-0QB0</u>
Enclosure	
design of the housing	with recess for label
shape of the enclosure front	rectangular
material of the enclosure	plastic
number of command points	2
product component	
EMERGENCY STOP device	No
protective collar	No
color of the enclosure top part	grey
delivery state	
● as a kit	No
pre-wired on strip terminal	Yes
	Yes Vertical
• pre-wired on strip terminal	
pre-wired on strip terminal fastening method of the enclosure	
pre-wired on strip terminal fastening method of the enclosure Actuator	Vertical
pre-wired on strip terminal fastening method of the enclosure Actuator design of the actuating element	Vertical Pushbutton / pushbutton
pre-wired on strip terminal fastening method of the enclosure Actuator design of the actuating element suitability for use EMERGENCY OFF switch	Vertical Pushbutton / pushbutton No
pre-wired on strip terminal fastening method of the enclosure Actuator design of the actuating element suitability for use EMERGENCY OFF switch product feature lockout	Vertical Pushbutton / pushbutton No No
pre-wired on strip terminal fastening method of the enclosure Actuator design of the actuating element suitability for use EMERGENCY OFF switch product feature lockout product extension optional light source	Vertical Pushbutton / pushbutton No No No

number of contact modules	2
type of unlocking device	A = none / B = none
Front ring	
product component front ring	Yes
design of the front ring	Standard
material of the front ring	plastic
color of the front ring	black
Holder	
material of the holder	Plastic
Display	
number of LED modules	0
General technical data	
product function	
 positive opening 	Yes
 EMERGENCY OFF function 	No
EMERGENCY STOP function	No
protection class IP	IP66, IP67, IP69(IP69K)
degree of protection NEMA rating	1, 2, 3, 3R, 4, 4X, 12K, 13
shock resistance	
 according to IEC 60068-2-27 	sinusoidal half-wave 15g / 11 ms
for railway applications according to EN 61373	Category 1, Class B
vibration resistance	
according to IEC 60068-2-6	10 500 Hz: 5g
for railway applications according to EN 61373	Category 1, Class B
reference code according to IEC 81346-2	S
continuous current of the C characteristic MCB	10 A; for a short-circuit current smaller than 400 A 10 A
continuous current of the quick DIAZED fuse link continuous current of the DIAZED fuse link gG	10 A 10 A
Substance Prohibitance (Date)	10/A
SUBstance Promotance (Date)	Blei - 7439-92-1
	Bleimonoxid (Bleioxid) - 1317-36-8
operating voltage	
• at AC	
— at 50 Hz rated value	18 31.6 V
— at 60 Hz rated value	18 31.6 V
at DC rated value	18 31.6 V
cable entry type	Adapter ASI shaped cable (insulation displacement method) M20 cable entry
Communication/ Protocol	
design of the interface for communication	AS-i
type of electrical connection of the communication interface	Insulation piercing technology top/right
Auxiliary circuit	Silveralley
design of the contacts of auxiliary contacts	Silver alloy
number of NC contacts for auxiliary contacts number of NO contacts for auxiliary contacts	1
Connections/ Terminals	
type of electrical connection of modules and accessories	Spring-type terminal
type of electrical connection of modules and accessories	Adapter ASI shaped cable (insulation displacement method)
tightening torque of the screws in the bracket	1 1.2 N·m
tightening torque of fixing screws in the enclosure cover	1.5 1.7 N·m
Ambient conditions	
ambient temperature	
during operation	-25 +70 °C
during storage	-40 +80 °C
environmental category during operation according to IEC	3M6, 3S2, 3B2, 3C3, 3K6 (with relative air humidity of 10 95%, no
60721	condensation in operation permitted for all devices behind front panel)
Environmental footprint	
Environmental Product Declaration(EPD)	Yes
Global Warming Potential [CO2 eq] total	0.787 kg
Global Warming Potential [CO2 eq] during manufacturing	0.566 kg
Global Warming Potential [CO2 eq] during operation	0.235 kg
global warming potential [CO2 eq] after end of life	-0.015 kg

Installation/ mounting/ dimensions		
fastening method of modules and accessories	Floor mounting	
height	134.4 mm	
width	85 mm	
depth	75 mm	
shape of the installation opening	round	
Accessories		
number of labels	2	
marking of the name plate for command devices	A = O / B = I	
color of the label	A = black / B = black	
number of inscription plates	0	
Approvals Certificates		

General Product Approval

 Image: Confirmation of Conformity
 Image: Confirmation of Confirmatio Confirmation of Confirmation of Confirmation of Con

 UK
 Special Test Certificate
 Type Test Certificates/Test Report
 Confirmation
 Environmental Confirmations

Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3SU1802-0AC10-4HB1

Cax online generator


http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3SU1802-0AC10-4HB1


Service&Support (Manuals, Certificates, Characteristics, FAQs,...)


https://support.industry.siemens.com/cs/ww/en/ps/3SU1802-0AC10-4HB1


Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)

http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3SU1802-0AC10-4HB1&lang=en









last modified:

11/7/2023 🖸