## SIEMENS

## Data sheet

## 3SU1806-0AA00-0AB1



Enclosure for command devices, 22 mm, round, Enclosure material plastic, enclosure top part gray, 6 control points plastic, Recess for labels, without equipment

product brand name	SIRIUS ACT				
product designation	Enclosures				
product type designation	3SU1				
Enclosure					
design of the housing	with recess for label				
shape of the enclosure front	rectangular				
material of the enclosure	plastic				
number of command points	6				
product component protective collar	No				
color of the enclosure top part	grey				
fastening method of the enclosure	Vertical / horizontal				
General technical data					
protection class IP	IP66, IP67, IP69(IP69K)				
degree of protection NEMA rating	1, 2, 3, 3R, 4, 4X, 12, 13				
shock resistance for railway applications according to EN 61373	Category 1, Class B				
vibration resistance for railway applications according to EN 61373	Category 1, Class B				
Substance Prohibitance (Date)	10/01/2014				
cable entry type	Without				
Connections/ Terminals					
type of electrical connection on enclosure	Cable routing above and below, both 1 x M25				
tightening torque of fixing screws in the enclosure cover	1.5 1.7 N·m				
Ambient conditions					
ambient temperature					
during operation	-25 +70 °C				
during storage	-40 +80 °C				
environmental category during operation according to IEC 60721	3M6, 3S2, 3B2, 3C3, 3K6 (with relative air humidity of 10 95%, no condensation in operation permitted for all devices behind front panel)				
Installation/ mounting/ dimensions					
fastening method of modules and accessories	Floor mounting				
height	280 mm				
width	85 mm				
depth	64 mm				
mounting diameter	22.3 mm				
	0.4 mm				
positive tolerance of installation diameter	0.4 mm				
positive tolerance of installation diameter Approvals Certificates	0.4 mm				


SP SM	<u>Confirmation</u>	DVE VDE	EHC	UK CA	CE EG-Konf.	
Test Certificates		Marine / Shipping				
<u>Special Test Certific-</u> <u>ate</u>	<u>Type Test Certific-</u> ates/Test Report	ABS	Lloyd's Register urs	PRS	RINA	
other	Environment					
<u>Confirmation</u>	Environmental Con- firmations					
Further information						
Siemens has decided to exit the Russian market (see here). https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business						
Siemens is working on the renewal of the current EAC certificates. Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).						
Information on the packaging https://support.industry.siemens.com/cs/ww/en/view/109813875						
Information- and Downloadcenter (Catalogs, Brochures,)						

https://www.siemens.com/ic10 Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3SU1806-0AA00-0AB1

Cax online generator

Cax online generator http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3SU1806-0AA00-0AB1 Service&Support (Manuals, Certificates, Characteristics, FAQs,...) https://support.industry.siemens.com/cs/ww/en/ps/3SU1806-0AA00-0AB1 Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax\_de.aspx?mlfb=3SU1806-0AA00-0AB1&lang=en



last modified:

1/26/2022 🖸