## **SIEMENS**

## **Data sheet**



Enclosure for command devices, 22 mm, round, Enclosure material metal, Enclosure top part yellow, with protective collar, 1 control point, without equipment, floor mounting, 1xM20 each on top and bottom

product brand name	SIRIUS ACT	
product designation	Enclosures	
product type designation	3SU1	
Enclosure		
design of the housing	with protective collar	
shape of the enclosure front	Square	
material of the enclosure	metal	
number of command points	1	
product component protective collar	Yes	
color of the enclosure top part	yellow	
fastening method of the enclosure	Vertical	
General technical data		
protection class IP	IP66, IP67, IP69(IP69K)	
degree of protection NEMA rating	1, 2, 3, 3R, 4, 4X, 12, 13	
shock resistance for railway applications according to EN 61373	Category 1, Class B	
vibration resistance for railway applications according to EN 61373	Category 1, Class B	
Substance Prohibitance (Date)	10/01/2014	
SVHC substance name	Blei - 7439-92-1	
cable entry type	Without	
Connections/ Terminals		
type of electrical connection on enclosure	Cable routing above and below, both 1 x M20	
tightening torque of fixing screws in the enclosure cover	1.5 1.7 N·m	
mbient conditions		
ambient temperature		
during operation	-25 +70 °C	
during storage	-40 +80 °C	
environmental category during operation according to IEC 60721	3M6, 3S2, 3B2, 3C3, 3K6 (with relative air humidity of 10 95%, no condensation in operation permitted for all devices behind front panel)	
nstallation/ mounting/ dimensions		
fastening method of modules and accessories	Floor mounting	
height	89.4 mm	
width	85 mm	
depth	112.5 mm	
mounting diameter	22.3 mm	
positive tolerance of installation diameter	0.4 mm	
pprovals Certificates		
General Product Approval		Declaration of Conformity



Confirmation









**Declaration of Conformity** 

**Test Certificates** 

Marine / Shipping



Type Test Certificates/Test Report

Special Test Certificate







Marine / Shipping

other

Environment



Confirmation

Environmental Confirmations

## Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3SU1851-0AA00-0AC2

Cax online generator


 $\underline{\text{http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en\&mlfb=3SU1851-0AA00-0AC2}\\$ 


Service&Support (Manuals, Certificates, Characteristics, FAQs,...)


https://support.industry.siemens.com/cs/ww/en/ps/3SU1851-0AA00-0AC2

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)

http://www.automation.siemens.com/bilddb/cax\_de.aspx?mlfb=3SU1851-0AA00-0AC2&lang=en







last modified: 9/5/2023 🖸