SIEMENS

Data sheet 3UF7013-1AU00-0



Basic unit SIMOCODE pro V EIP, EtherNet/IP, medium redundancy DLR, Web server, transmission rate 100 Mbps, 2 x bus connection via RJ45, 4I/3O freely parameterizable, Us: 110...240 V AC/DC, input for thermistor connection Monostable relay outputs, expandable by extension modules

| product brand name | SIRIUS |
|-----------------------------------------------------------------------------|-------------------------|
| product designation | Motor management system |
| design of the product | basic unit 3 |
| product type designation | SIMOCODE pro V EIP |
| General technical data | |
| product function | |
| bus communication | Yes |
| data acquisition function | Yes |
| diagnostics function | Yes |
| password protection | Yes |
| • test function | Yes |
| maintenance function | Yes |
| product component | |
| input for thermistor connection | Yes |
| digital input | Yes |
| input for analog temperature sensors | No |
| input for ground fault detection | No |
| • relay output | Yes |
| product extension | |
| temperature monitoring module | Yes |
| current measuring module | Yes |
| current/voltage measuring module | Yes |
| • fail-safe digital I/O module | Yes |
| ground-fault monitoring module | Yes |
| control unit with display | Yes |
| • control unit | Yes |
| analog I/O module | Yes |
| apparent power consumption | 8.3 VA |
| consumed active power | 4.8 W |
| insulation voltage with degree of pollution 3 at AC rated value | 300 V |
| surge voltage resistance rated value | 4 000 V |
| protection class IP | IP20 |
| shock resistance | |
| • according to IEC 60068-2-27 | 15g / 11 ms |
| switching capacity current of the NO contacts of the relay outputs at AC-15 | |
| • at 24 V | 6 A |
| • at 120 V | 6 A |
| • at 230 V | 3 A |
| switching capacity current of the NO contacts of the relay outputs at DC-13 | |

| 24 \ | 0.4 |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------|
| • at 24 V | 2 A |
| • at 60 V | 0.55 A |
| • at 125 V | 0.25 A |
| mechanical service life (operating cycles) typical | 10 000 000 |
| electrical endurance (operating cycles) typical | 100 000 |
| buffering time in the event of power failure | 0.02 s |
| reference code according to IEC 81346-2 | F |
| continuous current of the NO contacts of the relay outputs | |
| ● at 50 °C | 6 A |
| • at 60 °C | 5 A |
| type of input characteristic | Type 1 in accordance with EN 61131-2 |
| Substance Prohibitance (Date) | 03/01/2017 |
| SVHC substance name | Blei - 7439-92-1 Bleimonoxid (Bleioxid) - 1317-36-8 Bleititanzirkonoxid - 12626-81-2 2,2',6,6'-Tetrabrom-4,4'-isopropylidendi - 79-94-7 |
| certificate of suitability | |
| • IECEx | Yes; IECEx PTB 18.0004X |
| according to ATEX directive 2014/34/EU | BVS 06 ATEX F001, PTB 18 ATEX 5003 X |
| acc. to Equipment and Protective System Intended for Use in Potentially Explosive Atmospheres Regulations 2016 (S.I. 2016 No.1107) | ITS21UKEX0464, ITS21UKEX0455X |
| according to UKCA | ITS21UKEX0464, ITS21UKEX0455X |
| explosion device group and category according to ATEX directive 2014/34/EU | II (2) G, II (2) D, I (M2) / I (1G/M2), II (1/2) G, II (1G/2D) |
| Electromagnetic compatibility | |
| EMC emitted interference according to IEC 60947-1 | class A |
| EMC immunity according to IEC 60947-1 | corresponds to degree of severity 3 |
| conducted interference | |
| due to burst according to IEC 61000-4-4 | 2 kV (power ports) / 1 kV (signal ports) |
| due to conductor-earth surge according to IEC 61000-4-5 | 2 kV |
| due to conductor-conductor surge according to IEC | 1 kV |
| 61000-4-5due to high-frequency radiation according to IEC 61000- | 10 V |
| 4-6 | |
| field-based interference according to IEC 61000-4-3 | 10 V/m |
| electrostatic discharge according to IEC 61000-4-2 | 6 kV contact discharge / 8 kV air discharge |
| conducted HF interference emissions according to CISPR11 | corresponds to degree of severity A |
| field-bound HF interference emission according to CISPR11 | corresponds to degree of severity A |
| Inputs/ Outputs | |
| product function | |
| parameterizable inputs | Yes |
| parameterizable outputs | Yes |
| number of inputs | 4 |
| for thermistor connection | 1 |
| number of digital inputs with a common reference potential | 4 |
| digital input version | |
| • type 1 acc. to IEC 61131 | Yes |
| input voltage at digital input at DC rated value | 24 V |
| number of outputs | 3 |
| number of semiconductor outputs | 0 |
| number of outputs as contact-affected switching element | 3 |
| switching behavior | monostable |
| type of relay outputs | Monostable |
| wire length for digital signals maximum | 300 m |
| wire length for thermistor connection | |
| with conductor cross-section = 0.5 mm² maximum | 50 m |
| with conductor cross-section = 0.5 mm² maximum with conductor cross-section = 1.5 mm² maximum | 150 m |
| with conductor cross-section = 1.5 mm² maximum with conductor cross-section = 2.5 mm² maximum | 250 m |
| Protective and monitoring functions | 200 |
| | |
| product function | Vee |
| asymmetry detection | Yes |

| blocking current evaluation | Yes |
|------------------------------------------------------------------|---------------|
| power factor monitoring | Yes |
| ground fault detection | Yes |
| phase failure detection | Yes |
| phase sequence recognition | Yes |
| voltage detection | Yes |
| monitoring of number of start operations | Yes |
| overvoltage detection | Yes |
| overcurrent detection 1 phase | Yes |
| undervoltage detection | Yes |
| undercurrent detection 1 phase | Yes |
| active power monitoring | Yes |
| product function | |
| current detection | Yes |
| overload protection | Yes |
| evaluation of thermistor motor protection | Yes |
| total cold resistance number of sensors in series maximum | 1.5 kΩ |
| response value of thermoresistor | 3 400 3 800 Ω |
| of the short-circuit control | 9 Ω |
| release value of thermoresistor | 1 500 1 650 Ω |
| Motor control functions | |
| product function | |
| parameterizable overload relay | Yes |
| circuit breaker control | Yes |
| direct start | Yes |
| reverse starting | Yes |
| star-delta circuit | Yes |
| star-delta reversing circuit | Yes |
| Dahlander circuit | Yes |
| Dahlander reversing circuit | Yes |
| pole-changing switch circuit | Yes |
| pole-changing switch reversing circuit | Yes |
| slide control | Yes |
| valve control | Yes |
| Communication/ Protocol | |
| protocol is supported | |
| PROFIBUS DP protocol | No |
| PROFINET IO protocol | No |
| PROFIsafe protocol | No |
| Modbus RTU | No |
| • EtherNet/IP | Yes |
| OPC UA Server | No |
| • LLDP | Yes |
| Address Resolution Protocol (ARP) | Yes |
| • SNMP | Yes |
| • HTTPS | No |
| • NTP | Yes |
| Media Redundancy Protocol (MRP) | No |
| number of interfaces | |
| according to PROFINET | 0 |
| according to PROFIBUS | 0 |
| according to Ethernet/IP | 2 |
| product function | |
| • web server | Yes |
| shared device | No |
| at the Ethernet interface Autocrossover | Yes |
| at the Ethernet interface Autonegotiation | Yes |
| at the Ethernet interface Autosensing | Yes |
| is supported Device Level Ring (DLR) | Yes |
| is supported PROFINET system redundancy (S2) | No |
| supports PROFlenergy measured values | No |
| | |

| a guanarta DDOElanargy abutdawa | No |
|--------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| supports PROFlenergy shutdown transfer rate maximum | No 100 Mbit/s |
| identification & maintenance function | TOU INIDIUS |
| I&M0 - device-specific information | No |
| • | No |
| I&M1 - higher level designation/location designation I&M2 - installation date | No |
| | |
| I&M3 - comment type of electrical appropriate of the communication interface. | No |
| type of electrical connection of the communication interface | 2x RJ45 |
| Installation/ mounting/ dimensions | |
| mounting position | any |
| fastening method | screw and snap-on mounting |
| height | 111 mm |
| width | 45 mm |
| depth | 124 mm |
| required spacing | |
| • top | 40 mm |
| • bottom | 40 mm |
| • left | 0 mm |
| • right | 0 mm |
| Connections/ Terminals | |
| product component removable terminal for auxiliary and control circuit | Yes |
| type of connectable conductor cross-sections | |
| solid | 1x (0.5 4.0 mm²), 2x (0.5 2.5 mm²) |
| | 1x (0.5 2.5 mm²), 2x (0.5 1.5 mm²) |
| finely stranded with core end processing for AWG cables solid | |
| for AWG cables stranded | 1x (20 12), 2x (20 14) |
| | 1x (20 14), 2x (20 16) 0.8 1.2 N·m |
| tightening torque with screw-type terminals | |
| tightening torque [lbf-in] with screw-type terminals | 7 10.3 lbf-in |
| Ambient conditions | |
| installation altitude at height above sea level | 0.000 |
| • 1 maximum | 2 000 m |
| • 2 maximum | 3 000 m; max. +50 °C (no protective separation) |
| • 3 maximum | 4 000 m; max. +40 °C (no protective separation) |
| ambient temperature | o - 0000 |
| during operation | -25 +60 °C |
| during storage | -40 +80 °C |
| during transport | -40 +80 °C |
| environmental category | |
| during operation according to IEC 60721 | 3K6 (no formation of ice, no condensation, relative humidity 10 95%), 3C3 (no salt mist), 3S2 (sand must not get into the devices), 3M6 |
| during storage according to IEC 60721 | 1K6 (no condensation, relative humidity 10 95%), 1C2 (no salt mist), 1S2 |
| adding storage according to IEO 00721 | (sand must not get into the devices), 1M4 |
| during transport according to IEC 60721 | 2K2, 2C1, 2S1, 2M2 |
| relative humidity | |
| during operation | 5 95 % |
| contact rating of auxiliary contacts according to UL | B300 / R300 |
| Short-circuit protection | |
| design of short-circuit protection per output | Fuse links: gG 6 A, quick-response 10 A (IEC 60947-5-1), miniature circuit- |
| | breaker C char.: 1.6 A (IEC 60947-5-1) or 6 A (I_K < 500 A) |
| Electrical Safety | |
| touch protection against electrical shock | finger-safe |
| Galvanic isolation | |
| (electrically) protective separation according to IEC 60947-1 | All circuits with protective separation (double creepage paths and clearances), the information in the "Protective Separation" test report, No. A0258, must be observed (link see further information) |
| Control circuit/ Control | |
| product function soft starter control | Yes |
| type of voltage of the control supply voltage | AC/DC |
| control supply voltage at AC | |
| • at 50 Hz rated value | 110 240 V |
| • at 60 Hz rated value | 110 240 V |
| | |

| control supply voltage frequency | |
|--------------------------------------------------------------------------|-----------|
| • 1 rated value | 50 Hz |
| • 2 rated value | 60 Hz |
| relative symmetrical tolerance of the control supply voltage frequency | 5 % |
| control supply voltage at DC | |
| rated value | 110 240 V |
| operating range factor control supply voltage rated value at DC | |
| • initial value | 0.85 |
| • full-scale value | 1.1 |
| operating range factor control supply voltage rated value at AC at 50 Hz | |
| • initial value | 0.85 |
| • full-scale value | 1.1 |
| operating range factor control supply voltage rated value at AC at 60 Hz | |
| • initial value | 0.85 |
| • full-scale value | 1.1 |
| inrush current peak | |
| • at 240 V | 5 A |
| duration of inrush current peak | |
| • at 240 V | 1 ms |
| Approvals Certificates | |

General Product Approval







Confirmation





EMC

For use in hazardous locations











IECEX



Explosion Protection Certificate

Test Certificates

Marine / Shipping

Type Test Certificates/Test Report

Special Test Certific-<u>ate</u>

Special Test Certific-<u>ate</u>







Marine / Shipping

other



Confirmation

Miscellaneous

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3UF7013-1AU00-0

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3UF7013-1AU00-0


Service&Support (Manuals, Certificates, Characteristics, FAQs,...)


https://support.industry.siemens.com/cs/ww/en/ps/3UF7013-1AU00-0


Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3UF7013-1AU00-0&lang=en

Test report No. A0258, protective separation

https://support.industry.siemens.com/cs/ww/en/view/109748152







last modified: 11/7/2023 🖸