## **SIEMENS**

Data sheet 3UF7122-1AA01-0



Current/voltage measuring module for dry-running protection of centrifugal pumps in hazardous areas; set current 10 ... 115 A, voltage measurement up to 690 V, width 55 mm, straight-through transformer

product brand name	SIRIUS		
product designation	Current/voltage measuring module		
General technical data			
product function			
current measurement	Yes		
<ul> <li>voltage measurement</li> </ul>	Yes		
<ul> <li>active power measurement</li> </ul>	Yes		
<ul> <li>energy measurement</li> </ul>	Yes		
<ul> <li>frequency measurement</li> </ul>	Yes		
<ul> <li>active power monitoring for pump dry-run according to Ignition protection type Ex b</li> </ul>	Yes		
measuring procedure for current measurement	TRMS		
current measuring range extension with external current transformers	No		
measuring procedure for voltage measurement	TRMS		
measurable supply voltage between the line conductors at AC maximum rated value	690 V		
line conductors and neutral conductors internal resistance for voltage measurement	RC-based voltage divider		
product component			
input for thermistor connection	No		
consumed active power	0.5 W		
insulation voltage			
<ul> <li>with degree of pollution 3 at AC rated value</li> </ul>	690 V		
<ul> <li>for wires of main circuit according to IEC 60947-1 rated value</li> </ul>	6 kV		
surge voltage resistance rated value	6 000 V		
protection class IP	IP20		
shock resistance according to IEC 60068-2-27	15g / 11 ms; with basic unit snapped on		
Substance Prohibitance (Date)	05/28/2009		
SVHC substance name	Blei - 7439-92-1 Bleimonoxid (Bleioxid) - 1317-36-8 2-Methyl-1-(4-methylthiophenyl)-2-morpho - 71868-10-5		
certificate of suitability			
• IECEx	Yes; IECEx PTB 18.0004X		
<ul> <li>according to ATEX directive 2014/34/EU</li> </ul>	BVS 06 ATEX F001, PTB 18 ATEX 5003 X		
according to UKCA	ITS21UKEX0464, ITS21UKEX0455X		
explosion device group and category according to ATEX directive 2014/34/EU	II (2) G, II (2 ) D, I (M2) / I (1G/M2), II (1/2) G, II (1G/2D)		
Electromagnetic compatibility			
EMC emitted interference according to IEC 60947-1	class A		
EMC immunity according to IEC 60947-1	corresponds to degree of severity 3		
conducted interference			

<ul> <li>due to burst according to IEC 61000-4-4</li> </ul>	2 kV		
<ul> <li>due to conductor-earth surge according to IEC 61000-4-5</li> </ul>	2 kV		
<ul> <li>due to conductor-conductor surge according to IEC 61000-4-5</li> </ul>	1 kV		
field-based interference according to IEC 61000-4-3	10 V/m		
Inputs/ Outputs			
number of outputs as contact-affected switching element	0		
Protective and monitoring functions			
product function			
power factor monitoring	Yes		
ground-fault monitoring	Yes		
voltage detection	Yes		
trip class	CLASS 5E		
product function			
current detection	Yes		
overload protection	Yes		
Precision			
measuring precision			
of frequency measurement	+/- 1.5 %, 7.5 A 230 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos		
- or nequency measurement	phi (0.51), 50/60 Hz, 25 °C		
• for current measurement 1	+/- 1.5 %, in range 7.5 A 230 A, in range 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), 50/60 Hz, 25 $^{\circ}\mathrm{C}$		
• for current measurement 2	+/- 3%, in range 230 A 920 A, in range 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), 50/60 Hz, 25 $^{\circ}\text{C}$		
• for voltage measurement 1	+/- 1.5 %, in range 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), 50/60 Hz, 25 $^{\circ}\mathrm{C}$		
• at cos phi-measurement 1	+/- 1.5 %, 7.5 A 230 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos phi (0.51), 50/60 Hz, 25 °C		
at cos phi-measurement 2	+/- 5%, 230 A 920 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cosphi (0.51), 50/60 Hz, 25 $^{\circ}\mathrm{C}$		
at active power measurement 1	+/- 5%, 15 A 400 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cosphi (0.51), 50/60 Hz, 25 $^{\circ}\mathrm{C}$		
at active power measurement 2	+/- 10%, 230 A 920 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cosphi (0.51), 50/60 Hz, 25 °C		
at energy measurement 1	+/- 5%, 7.5 A 230 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cosphi (0.51), 50/60 Hz, 25 °C		
at energy measurement 2	+/- 10%, 230 A 920 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cosphi (0.51), 50/60 Hz, 25 °C		
at apparent power measurement 1	+/- 3%, 7.5 A 230 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cosphi (0.51), 50/60 Hz, 25 °C		
at apparent power measurement 2	+/- 5 %, 230 A 920 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos phi (0.51), 50/60 Hz, 25 °C		
accuracy of ground-fault monitoring	In the range 30 % 120 %/Is: +/- 10 % (Class CI-A), in range 15 % 30 % le: +/- 25 % (Class CI-B), both values acc. to IEC 60947-1 Annex T		
temperature drift per °C	0.01 %/°C; Reference temperature: 25°C		
measured variable frequency	45 65 Hz		
Installation/ mounting/ dimensions			
mounting position	any		
fastening method	screw and snap-on mounting		
height	94 mm		
width	55 mm		
depth	91 mm		
required spacing	20		
• top	30 mm		
• bottom	30 mm		
• left	0 mm		
• right	0 mm		
diameter of inlet opening	14 mm		
diameter of inlet opening for current measurement	14 mm		
Connections/ Terminals			
type of electrical connection at the measurement inputs for voltage	screw-type terminals		
type of connectable conductor cross-sections at the measurement inputs for voltage			
finely stranded with core end processing	1x (0.25 2.5 mm²), 2x (0.25 1.0 mm²)		
-			

• solid	1x (0.25 2.5 mm²), 2x (0.25 .	1 () mm²)		
for AWG cables solid	1x (24 14), 2x (24 18)			
for AWG cables stranded	1x (20 14), 2x (20 16)			
tightening torque at the measurement inputs for voltage	0.5 0.6 N·m			
tightening torque [lbf·in] at the measurement inputs for voltage	4.4 5.3 lbf·in			
Ambient conditions				
installation altitude at height above sea level				
• 1 maximum	2 000 m			
• 2 maximum	3 000 m; max. +50 °C (no protective separation)			
• 3 maximum	4 000 m; max. +40 °C (no protective separation)			
ambient temperature				
<ul> <li>during operation</li> </ul>	-25 +60 °C			
during storage	-40 +80 °C			
during transport	-40 +80 °C			
environmental category				
<ul> <li>during operation according to IEC 60721</li> </ul>	3K6 (no formation of ice, no condensation, relative humidity 10 95%), 3C3 (no salt mist), 3S2 (sand must not get into the devices), 3M6			
during storage according to IEC 60721	1K6 (no condensation, relative humidity 10 95%), 1C2 (no salt mist), 1S2 (sand must not get into the devices), 1M4			
<ul> <li>during transport according to IEC 60721</li> </ul>	2K2, 2C1, 2S1, 2M2			
relative humidity during operation	10 95 %			
Short-circuit protection				
product function short circuit protection	No			
Galvanic isolation				
Galvanic isolation (electrically) protective separation according to IEC 60947-1	All circuits with protective separ the information in the "Protectiv observed (link see further inform	e Separation" test report,		
	the information in the "Protective	e Separation" test report,		
(electrically) protective separation according to IEC 60947-1	the information in the "Protective	e Separation" test report,		
(electrically) protective separation according to IEC 60947-1  Main circuit	the information in the "Protectiv observed (link see further information)	e Separation" test report,		
(electrically) protective separation according to IEC 60947-1  Main circuit  number of poles for main current circuit  adjustable current response value current of the current-	the information in the "Protectivobserved (link see further information) 3	e Separation" test report,		
(electrically) protective separation according to IEC 60947-1  Main circuit  number of poles for main current circuit  adjustable current response value current of the current-dependent overload release	the information in the "Protectivobserved (link see further information) 3	e Separation" test report,		
(electrically) protective separation according to IEC 60947-1  Main circuit  number of poles for main current circuit  adjustable current response value current of the current-dependent overload release  operating voltage	the information in the "Protectivobserved (link see further information) 3	e Separation" test report,		
(electrically) protective separation according to IEC 60947-1  Main circuit  number of poles for main current circuit  adjustable current response value current of the current-dependent overload release  operating voltage  • at AC	the information in the "Protective observed (link see further informations) and the information of the information in the "Protective observed (link see further information of the information in the "Protective observed (link see further information of the inf	e Separation" test report,		
(electrically) protective separation according to IEC 60947-1  Main circuit  number of poles for main current circuit  adjustable current response value current of the current-dependent overload release  operating voltage  • at AC  — at 50 Hz rated value	the information in the "Protective observed (link see further information of the function of t	e Separation" test report,		
(electrically) protective separation according to IEC 60947-1  Main circuit  number of poles for main current circuit  adjustable current response value current of the current-dependent overload release  operating voltage  • at AC  — at 50 Hz rated value  — at 60 Hz rated value	the information in the "Protective observed (link see further information of the see further	e Separation" test report,		
Main circuit  number of poles for main current circuit adjustable current response value current of the current-dependent overload release operating voltage  • at AC  — at 50 Hz rated value — at 60 Hz rated value operating frequency rated value	the information in the "Protective observed (link see further information of the see further	e Separation" test report,		
(electrically) protective separation according to IEC 60947-1  Main circuit  number of poles for main current circuit  adjustable current response value current of the current-dependent overload release  operating voltage  • at AC  — at 50 Hz rated value  — at 60 Hz rated value  operating frequency rated value  Control circuit/ Control	the information in the "Protective observed (link see further information of the see further	e Separation" test report,		
(electrically) protective separation according to IEC 60947-1  Main circuit  number of poles for main current circuit  adjustable current response value current of the current-dependent overload release  operating voltage  • at AC  — at 50 Hz rated value — at 60 Hz rated value  operating frequency rated value  Control circuit/ Control  type of voltage	the information in the "Protective observed (link see further information	e Separation" test report,		
Main circuit  number of poles for main current circuit  adjustable current response value current of the current-dependent overload release  operating voltage  • at AC  — at 50 Hz rated value  — at 60 Hz rated value  operating frequency rated value  Control circuit/ Control  type of voltage  inrush current maximum	the information in the "Protective observed (link see further information	e Separation" test report,		



Confirmation









IECEx

## For use in hazardous locations









Explosion Protection Certificate





## **Test Certificates**

Marine / Shipping

Type Test Certificates/Test Report

Special Test Certificate

Special Test Certificate









Confirmation



Profibus

## Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3UF7122-1AA01-0

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3UF7122-1AA01-0

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)


https://support.industry.siemens.com/cs/ww/en/ps/3UF7122-1AA01-0


Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)


http://www.automation.siemens.com/bilddb/cax\_de.aspx?mlfb=3UF7122-1AA01-0&lang=en

Test report No. A0258, protective separation

https://support.industry.siemens.com/cs/ww/en/view/109748152







last modified: 8/16/2023 🖸