SIEMENS

Data sheet

6AG1315-6FF04-2AB0



SIPLUS S7-300 CPU 315F-2DP based on 6ES7315-6FF04-0AB0 with conformal coating, -25...+60 °C, fail-safe module with MPI integrated power supply 24 V DC, work memory 384 KB, 40 mm width, 2nd interface DP master/ slave Micro Memory Card required

Figure similar

General information	
Product function	
 Isochronous mode 	Yes
Engineering with	
Programming package	STEP 7 V5.5 + SP1 or higher or STEP 7 V5.2 + SP1 or higher with HSP 218 + Distributed Safety
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
external protection for power supply lines (recommendation)	2 A min.
Mains buffering	
 Mains/voltage failure stored energy time 	5 ms
 Repeat rate, min. 	1 s
Input current	
Current consumption (rated value)	850 mA
Current consumption (in no-load operation), typ.	150 mA
Inrush current, typ.	3.5 A
l²t	1 A ² ·s
Power loss	
Power loss, typ.	4.5 W
Memory	
Work memory	
• integrated	384 kbyte
• expandable	No
Load memory	
• Plug-in (MMC)	Yes
Plug-in (MMC), max.	8 Mbyte
 Data management on MMC (after last programming), min. 	10 y
Backup	
• present	Yes; Guaranteed by MMC (maintenance-free)
without battery	Yes; Program and data
CPU processing times	
for bit operations, typ.	0.05 μs
for word operations, typ.	0.09 µs
for fixed point arithmetic, typ.	0.12 µs

or floating point arithmetic, typ.	0.45 μs
PU-blocks	
Number of blocks (total)	1 024; (DBs, FCs, FBs); the maximum number of loadable blocks can
	be reduced by the MMC used.
DB	4.004.14.40000
Number, max.	1 024; Number range: 1 to 16000
• Size, max.	64 kbyte
FB	
Number, max.	1 024; Number range: 0 to 7999
• Size, max.	64 kbyte
FC	
Number, max.	1 024; Number range: 0 to 7999
Size, max.	64 kbyte
OB .	
Number, max.	see instruction list
• Size, max.	64 kbyte
 Number of free cycle OBs 	1; OB 1
 Number of time alarm OBs 	1; OB 10
 Number of delay alarm OBs 	2; OB 20, 21
 Number of cyclic interrupt OBs 	4; OB 32, 33, 34, 35
 Number of process alarm OBs 	1; OB 40
 Number of DPV1 alarm OBs 	3; OB 55, 56, 57
 Number of isochronous mode OBs 	1; OB 61
 Number of startup OBs 	1; OB 100
Number of asynchronous error OBs	5; OB 80, 82, 85, 86, 87
Number of synchronous error OBs	2; OB 121, 122
Nesting depth	
per priority class	16
additional within an error OB	4
ounters, timers and their retentivity	
S7 counter	
Number	256
Retentivity	250
— adjustable	Yes
— lower limit	0
— upper limit	255
— preset	Z 0 to Z 7
Counting range	
— lower limit	0
— upper limit	999
EC counter	
• present	Yes
• Type	SFB
Number	Unlimited (limited only by RAM capacity)
S7 times	
Number	256
Retentivity	
— adjustable	Yes
— lower limit	0
— upper limit	255
— preset	No retentivity
Time range	
— lower limit	10 ms
— upper limit	9 990 s
EC timer	Yes
EC timer ● present	Yes
EC timer • present • Type	SFB
EC timer • present	

Elog	
Flag ◆ Size, max.	2 048 byte
Retentivity available	Yes; MB 0 to MB 2 047
Retentivity available Retentivity preset	MB 0 to MB 15
Number of clock memories	
Data blocks	8; 1 memory byte
Retentivity adjustable	Yes; via non-retain property on DB
Retentivity adjustable Retentivity preset	Yes
Local data	165
• per priority class, max.	32 kbyte; Max. 2 KB per block
Address area	oz kojto, max. z ko por blook
I/O address area	
• Inputs	2 048 byte
• Outputs	2 048 byte
of which distributed	2 040 3910
— Inputs	2 048 byte
— Outputs	2 048 byte
Process image	
• Inputs	2 048 byte
• Outputs	2 048 byte
Inputs, adjustable	2 048 byte
Outputs, adjustable	2 048 byte
Inputs, default	384 byte
Outputs, default	384 byte
Subprocess images	
Number of subprocess images, max.	1
Digital channels	
• Inputs	16 384
— of which central	1 024
Outputs	16 384
— of which central	1 024
Analog channels	
• Inputs	1 024
— of which central	256
Outputs	1 024
— of which central	256
Hardware configuration	
Number of expansion units, max.	3
Number of DP masters	
• integrated	1
• via CP	4
Number of operable FMs and CPs (recommended)	
• FM	8
• CP, PtP	8
• CP, LAN	10
Rack	
Racks, max.	4
 Modules per rack, max. 	8
Time of day	
Clock	
Hardware clock (real-time)	Yes
retentive and synchronizable	Yes
Backup time	6 wk; At 40 °C ambient temperature
Deviation per day, max.	10 s; Typ.: 2 s
Behavior of the clock following POWER-ON	Clock continues running after POWER OFF
Behavior of the clock following expiry of backup	the clock continues at the time of day it had when power was switched
period period	off
Operating hours counter	
Number	1
 Number/Number range 	0

a Dange of values	0 to 2/24 hours (when using CEC 101)
Range of values Cranularity	0 to 2^31 hours (when using SFC 101) 1 h
Granularityretentive	Yes; Must be restarted at each restart
Clock synchronization	res, must be restarted at each restart
• supported	Yes
• to MPI, master	Yes
• to MPI, slave	Yes
• to DP, master	Yes; With DP slave only slave clock
• to DP, slave	Yes
• in AS, master	Yes
• in AS, slave	No
Digital inputs	
Number of digital inputs	0
Digital outputs	
Number of digital outputs	0
Analog inputs	
Number of analog inputs	0
Analog outputs	
Number of analog outputs	0
Interfaces	
Number of industrial Ethernet interfaces	0
Number of PROFINET interfaces	0
Number of RS 485 interfaces	2
Number of RS 422 interfaces	0
1. Interface	
Interface type	Integrated RS 485 interface
Isolated	No
Interface types	
• RS 485	Yes
 Output current of the interface, max. 	200 mA
Protocols	
• MPI	Yes
 PROFIBUS DP master 	No
 PROFIBUS DP slave 	No
 Point-to-point connection 	No
MPI	
 Transmission rate, max. 	187.5 kbit/s
Services	
— PG/OP communication	Yes
— Routing	Yes
 Global data communication 	Yes
 — S7 basic communication 	Yes
— S7 communication	Yes; Only server, configured on one side
 S7 communication, as client 	No
— S7 communication, as server	Yes
2. Interface	
Interface type	Integrated RS 485 interface
Isolated	Yes
Interface types	
• RS 485	Yes
Output current of the interface, max.	200 mA
Protocols	Na
• MPI	No
PROFIBUS DP master	Yes
PROFIBUS DP slave Deint to project compaction	Yes
Point-to-point connection PROFIBLE DR moster	No
PROFIBUS DP master	42 Mhit/a
Transmission rate, max. Number of DR claves, max.	12 Mbit/s
 Number of DP slaves, max. 	124; Per station

Convince	
Services	Voc
— PG/OP communication	Yes
— Routing	Yes
Global data communication	No
— S7 basic communication	Yes; I blocks only
— S7 communication	Yes; Only server, configured on one side
 S7 communication, as client 	No
 S7 communication, as server 	Yes
— Equidistance	Yes
— Isochronous mode	Yes; OB 61
— SYNC/FREEZE	Yes
 Activation/deactivation of DP slaves 	Yes
 Number of DP slaves that can be 	8
simultaneously activated/deactivated, max.	
— DPV1	Yes
Address area	
— Inputs, max.	2 048 byte
— Outputs, max.	2 048 byte
User data per DP slave	
— Inputs, max.	244 byte
— Outputs, max.	244 byte
PROFIBUS DP slave	
GSD file	The latest GSD file is available at: http://www.siemens.com/profibus-gsd
 Transmission rate, max. 	12 Mbit/s
 automatic baud rate search 	Yes; only with passive interface
 Address area, max. 	32
 User data per address area, max. 	32 byte
Services	·
— PG/OP communication	Yes
— Routing	Yes; Only with active interface
Global data communication	No
— S7 basic communication	No
— S7 communication	Yes; Only server, configured on one side
— S7 communication, as client	No
	Yes
— S7 communication, as server	
 Direct data exchange (slave-to-slave communication) 	Yes
— DPV1	No
Transfer memory	
— Inputs	244 byte
— Outputs	244 byte
	244 Dyte
Protocols	V
PROFIsafe	Yes
communication functions / header	
PG/OP communication	Yes
Data record routing	Yes
Global data communication	
supported	Yes
 Number of GD loops, max. 	8
 Number of GD packets, max. 	8
 Number of GD packets, transmitter, max. 	8
 Number of GD packets, receiver, max. 	8
Size of GD packets, max.	22 byte
Size of GD packet (of which consistent), max.	22 byte
S7 basic communication	
• supported	Yes
User data per job, max.	76 byte
User data per job (of which consistent), max.	76 byte; 76 bytes (with X_SEND or X_RCV); 64 bytes (with X_PUT or
	X_GET as server)
S7 communication	
supported	Yes
· ·	

• as server	Yes
• as client	Yes; Via CP and loadable FB
User data per job, max.	180 byte; With PUT/GET
User data per job (of which consistent), max.	240 byte; as server
S5 compatible communication	Very via CD and leadable 50
• supported	Yes; via CP and loadable FC
Number of connections • overall	16
usable for PG communication	15
reserved for PG communication	15
adjustable for PG communication, min.	1
adjustable for PG communication, max.	15
usable for OP communication	15
reserved for OP communication	1
adjustable for OP communication, min.	1
adjustable for OP communication, max.	15
usable for S7 basic communication	12
reserved for S7 basic communication	0
adjustable for S7 basic communication, min.	0
adjustable for S7 basic communication, max.	12
S7 message functions	
Number of login stations for message functions, max.	16; Depending on the configured connections for PG/OP and S7 basic
	communication
Process diagnostic messages	Yes
simultaneously active Alarm-S blocks, max.	300
Test commissioning functions	
Status block	Yes; Up to 2 simultaneously
Single step	Yes
Number of breakpoints	4
Status/control	
 Status/control variable 	Yes
Variables	Inputs, outputs, memory bits, DB, times, counters
 Number of variables, max. 	30
of which status variables, max.	30
— of which control variables, max.	14
Forcing	
- Faraina	Yes
• Forcing	
• Forcing, variables	Inputs, outputs
Forcing, variablesNumber of variables, max.	Inputs, outputs 10
Forcing, variablesNumber of variables, max.Diagnostic buffer	10
 Forcing, variables Number of variables, max. Diagnostic buffer present 	10 Yes
 Forcing, variables Number of variables, max. Diagnostic buffer present Number of entries, max. 	10 Yes 500
 Forcing, variables Number of variables, max. Diagnostic buffer present Number of entries, max. adjustable 	10 Yes 500 No
 Forcing, variables Number of variables, max. Diagnostic buffer present Number of entries, max. — adjustable — of which powerfail-proof 	10 Yes 500
 Forcing, variables Number of variables, max. Diagnostic buffer present Number of entries, max. — adjustable — of which powerfail-proof Number of entries readable in RUN, max. 	Yes 500 No 100; Only the last 100 entries are retained
 Forcing, variables Number of variables, max. Diagnostic buffer present Number of entries, max. — adjustable — of which powerfail-proof Number of entries readable in RUN, max. — adjustable 	Yes 500 No 100; Only the last 100 entries are retained Yes; From 10 to 499
 Forcing, variables Number of variables, max. Diagnostic buffer present Number of entries, max. — adjustable — of which powerfail-proof Number of entries readable in RUN, max. — adjustable — preset 	Yes 500 No 100; Only the last 100 entries are retained
 Forcing, variables Number of variables, max. Diagnostic buffer present Number of entries, max. — adjustable — of which powerfail-proof Number of entries readable in RUN, max. — adjustable — preset Service data 	Yes 500 No 100; Only the last 100 entries are retained Yes; From 10 to 499 10
 Forcing, variables Number of variables, max. Diagnostic buffer present Number of entries, max. adjustable of which powerfail-proof Number of entries readable in RUN, max. adjustable preset Service data can be read out 	Yes 500 No 100; Only the last 100 entries are retained Yes; From 10 to 499
 Forcing, variables Number of variables, max. Diagnostic buffer present Number of entries, max. — adjustable — of which powerfail-proof Number of entries readable in RUN, max. — adjustable — preset Service data can be read out Standards, approvals, certificates 	Yes 500 No 100; Only the last 100 entries are retained Yes; From 10 to 499 10 Yes
 Forcing, variables Number of variables, max. Diagnostic buffer present Number of entries, max. adjustable of which powerfail-proof Number of entries readable in RUN, max. adjustable preset Service data can be read out Standards, approvals, certificates CE mark 	Yes 500 No 100; Only the last 100 entries are retained Yes; From 10 to 499 10 Yes
Forcing, variables Number of variables, max. Diagnostic buffer present Number of entries, max. adjustable of which powerfail-proof Number of entries readable in RUN, max. adjustable preset Service data can be read out Standards, approvals, certificates CE mark UL approval	Yes 500 No 100; Only the last 100 entries are retained Yes; From 10 to 499 10 Yes Yes Yes Yes; File E239877
Forcing, variables Number of variables, max. Diagnostic buffer present Number of entries, max. adjustable of which powerfail-proof Number of entries readable in RUN, max. adjustable preset Service data can be read out Standards, approvals, certificates CE mark UL approval RCM (formerly C-TICK)	Yes 500 No 100; Only the last 100 entries are retained Yes; From 10 to 499 10 Yes Yes Yes Yes; File E239877 Yes
Forcing, variables Number of variables, max. Diagnostic buffer present Number of entries, max. adjustable of which powerfail-proof Number of entries readable in RUN, max. adjustable preset Service data can be read out Standards, approvals, certificates CE mark UL approval RCM (formerly C-TICK) KC approval	Yes 500 No 100; Only the last 100 entries are retained Yes; From 10 to 499 10 Yes Yes Yes; File E239877 Yes Yes
Forcing, variables Number of variables, max. Diagnostic buffer present Number of entries, max. adjustable of which powerfail-proof Number of entries readable in RUN, max. adjustable preset Service data can be read out Standards, approvals, certificates CE mark UL approval RCM (formerly C-TICK) KC approval EAC (formerly Gost-R)	Yes 500 No 100; Only the last 100 entries are retained Yes; From 10 to 499 10 Yes Yes Yes Yes; File E239877 Yes
 Forcing, variables Number of variables, max. Diagnostic buffer present Number of entries, max. — adjustable — of which powerfail-proof Number of entries readable in RUN, max. — adjustable — preset Service data can be read out Standards, approvals, certificates CE mark UL approval RCM (formerly C-TICK) KC approval EAC (formerly Gost-R) Use in hazardous areas 	Yes 500 No 100; Only the last 100 entries are retained Yes; From 10 to 499 10 Yes Yes Yes Yes; File E239877 Yes Yes Yes Yes
 Forcing, variables Number of variables, max. Diagnostic buffer present Number of entries, max. adjustable of which powerfail-proof Number of entries readable in RUN, max. adjustable preset Service data can be read out Standards, approvals, certificates CE mark UL approval RCM (formerly C-TICK) KC approval EAC (formerly Gost-R) Use in hazardous areas ATEX 	Yes 500 No 100; Only the last 100 entries are retained Yes; From 10 to 499 10 Yes Yes Yes; File E239877 Yes Yes
 Forcing, variables Number of variables, max. Diagnostic buffer present Number of entries, max. adjustable of which powerfail-proof Number of entries readable in RUN, max. adjustable preset Service data can be read out Standards, approvals, certificates CE mark UL approval RCM (formerly C-TICK) KC approval EAC (formerly Gost-R) Use in hazardous areas ATEX Railway application	Yes 500 No 100; Only the last 100 entries are retained Yes; From 10 to 499 10 Yes Yes Yes Yes; File E239877 Yes Yes Yes Yes Yes
 Forcing, variables Number of variables, max. Diagnostic buffer present Number of entries, max. adjustable of which powerfail-proof Number of entries readable in RUN, max. adjustable preset Service data can be read out Standards, approvals, certificates CE mark UL approval RCM (formerly C-TICK) KC approval EAC (formerly Gost-R) Use in hazardous areas ATEX 	Yes 500 No 100; Only the last 100 entries are retained Yes; From 10 to 499 10 Yes Yes Yes Yes; File E239877 Yes Yes Yes Yes

Ambient temperature during operation	
min.	-25 °C
• max.	60 °C
Ambient temperature during storage/transportation	
• min.	-40 °C
• max.	70 °C
Altitude during operation relating to sea level	
 Installation altitude above sea level, max. 	2 000 m
Ambient air temperature-barometric pressure- altitude	Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m)
Relative humidity	
With condensation, tested in accordance with IEC 60068-2-38, max.	100 %; RH incl. condensation/frost (no commissioning under condensation conditions)
Resistance	
Use in stationary industrial systems	
 to biologically active substances according to EN 60721-3-3 	Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna); Class 3B3 on request
 to chemically active substances according to EN 60721-3-3 	Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *
 to mechanically active substances according to EN 60721-3-3 	Yes; Class 3S4 incl. sand, dust, *
Use on ships/at sea	
 to biologically active substances according to EN 60721-3-6 	Yes; Class 6B2 mold and fungal spores (excluding fauna); Class 6B3 on request
 to chemically active substances according to EN 60721-3-6 	Yes; Class 6C3 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *
 to mechanically active substances according to EN 60721-3-6 	Yes; Class 6S3 incl. sand, dust; *
Usage in industrial process technology	
 Against chemically active substances acc. to EN 60654-4 	Yes; Class 3 (excluding trichlorethylene)
 Environmental conditions for process, measuring and control systems acc. to ANSI/ISA- 71.04 	Yes; Level GX group A/B (excluding trichlorethylene; harmful gas concentrations up to the limits of EN 60721-3-3 class 3C4 permissible); level LC3 (salt spray) and level LB3 (oil)
Remark	
 Note regarding classification of environmental conditions acc. to EN 60721, EN 60654-4 and ANSI/ISA-71.04 	* The supplied plug covers must remain in place over the unused interfaces during operation!
configuration / header	
Configuration software	
• STEP 7	Yes; V5.2 SP1 or higher with HW update
configuration / programming / header	
Command set	see instruction list
Nesting levels	8
System functions (SFC) System function blacks (SFR)	see instruction list
System function blocks (SFB)	see instruction list
Programming language	V
— LAD	Yes
— FBD	Yes
— STL	Yes
— SCL	Yes
— CFC	Yes
— GRAPH	Yes
— HiGraph®	Yes
Know-how protection	Von
User program protection/password protectionBlock encryption	Yes Yes; With S7 block Privacy
Block encryption Dimensions	163, WILLI OF DIOCK FITMACY
	40 mm
Width	40 mm 125 mm
Height Depth	130 mm
·	100 111111
Weights Weight approx	200 a
Weight, approx.	290 g

last modified: 8/24/2021 🖸