SIEMENS

Data sheet

6AG1343-1CX10-2XE0

product type designation



SIPLUS NET CP343-1 LEAN

SIPLUS NET CP 343-1 Lean based on 6GK7343-1CX10-0XE0 with conformal coating, -25...+60 °C, communications processor for connection of SIMATIC S7-300 to Industrial Ethernet via TCP/IP and UDP, multicast, send/receive with and without RFC1006, fetch/ write, S7 communication (server) PROFINET IO device integrated 2-port switch ERTEC 200, module replacement without PG, SNMP diagnostics, initialization via LAN,

| transfer rate | |
|--|--|
| transfer rate | |
| at the 1st interface | 10 100 Mbit/s |
| interfaces | |
| number of interfaces / acc. to Industrial Ethernet | 2 |
| number of electrical connections | |
| at the 1st interface / acc. to Industrial Ethernet | 2 |
| for power supply | 1 |
| type of electrical connection | |
| of Industrial Ethernet interface | RJ45 port |
| at the 1st interface / acc. to Industrial Ethernet | RJ45 port |
| type of electrical connection | |
| for power supply | 2-pole plugable terminal block |
| supply voltage, current consumption, power loss | |
| type of voltage / of the supply voltage | DC |
| supply voltage / 1 / from backplane bus | 5 V |
| supply voltage | 24 V |
| supply voltage / external | 24 V |
| supply voltage / external / at DC / rated value | 24 V |
| relative positive tolerance / at DC / at 24 V | 20 % |
| relative negative tolerance / at DC / at 24 V | 15 % |
| consumed current | |
| from backplane bus / at DC / at 5 V / typical | 0.2 A |
| from external supply voltage / at DC / at 24 V / typical | 0.16 A |
| from external supply voltage / at DC / at 24 V / maximum | 0.2 A |
| power loss [W] | 5.8 W |
| ambient conditions | |
| ambient temperature | |
| for vertical installation / during operation | -25 +40 °C |
| for horizontally arranged busbars / during operation | -25 +60 °C |
| during storage | -40 +70 °C |
| during transport | -40 +70 °C |
| installation altitude / at height above sea level / maximum | 5000 m |
| ambient condition / relating to ambient temperature - air pressure - installation altitude | Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m) // Tmin (Tmax - 10 K) at 795 hPa 658 hPa (+2 000 m +3 500 m) // Tmin (Tmax - 20 K) at 658 hPa 540 hPa (+3 500 m +5 000 m) |
| rolativo humidity | |

relative humidity

| with condensation / acc. to IEC 60068-2-38 / maximum | 100 %; RH including condensation/frost (no commissioning when condensation is present), horizontal installation |
|---|---|
| chemical resistance / to commercially available cooling lubricants | Yes; incl. airborne diesel and oil droplets |
| resistance to biologically active substances | |
| • conformity acc. to EN 60721-3-3 | Yes; Class 3B2 mold and fungal spores (excluding fauna), Class 3B3 on request |
| • conformity acc. to EN 60721-3-6 | Yes; Class 6B2 mold, fungal and dry rot spores (excluding fauna) |
| resistance to chemically active substances | |
| • conformity acc. to EN 60721-3-3 | Yes; Class 3C4 (RH < 75 %) incl. salt spray in accordance with EN 60068-2-52 (Severity 3). The supplied plug covers must remain in place on the unused interfaces during operation. |
| conformity acc. to EN 60721-3-6 | Yes |
| resistance to mechanically active substances | |
| conformity acc. to EN 60721-3-3 conformity acc. to EN 60721-3-6 | Yes; Class 3S4 incl. sand, dust. The supplied plug covers must remain in place over the unused interfaces during operation. Yes; Class 6S3 incl. sand, dust. The supplied plug covers must remain |
| | in place over the unused interfaces during operation. |
| coating / for equipped printed circuit board / acc. to EN 61086 | Yes; Class 2 for high availability |
| type of coating / protection against pollution according to EN 60664-3 | Yes; Protection of the type 1 |
| type of test / of the coating / acc. to MIL-I-46058C | Yes; Coating discoloration during service life possible |
| product conformity / of the coating / Qualification and Performance of Electrical Insulating Compound for Printed Board Assemblies acc. to IPC-CC-830A | Yes; Conformal coating, class A |
| protection class IP | IP20 |
| design, dimensions and weights | |
| module format | Compact module S7-300 single width |
| width | 40 mm |
| height | 125 mm |
| depth | 120 mm |
| net weight | 0.22 kg |
| fastening method | |
| • S7-300 rail mounting | Yes |
| performance data / open communication | |
| number of possible connections / for open communication / by means of SEND/RECEIVE blocks / maximum | 8 |
| data volume | |
| as user data per ISO on TCP connection / for open communication / by means of SEND/RECEIVE blocks / maximum | 8 Kibyte |
| as user data per TCP connection / for open communication / by means of SEND/RECEIVE blocks / maximum | 8 Kibyte |
| as user data per UDP connection / for open IE communication / by means of SEND/RECEIVE blocks / maximum | 2 Kibyte |
| number of Multicast stations | 8 |
| performance data / S7 communication | |
| number of possible connections / for S7 communication | |
| • maximum | 4 |
| service | |
| of SIMATIC communication / as server | Yes |
| performance data / multi-protocol mode | |
| number of active connections / with multi-protocol mode | 12 |
| · . | |
| performance data / PROFINET communication / as PN IO | controller |
| performance data / PROFINET communication / as PN IO o | |
| product function / PROFINET IO controller | No |
| product function / PROFINET IO controller performance data / PROFINET communication / as PN IO c | No levice |
| product function / PROFINET IO controller performance data / PROFINET communication / as PN IO o product function / PROFINET IO device | No |
| product function / PROFINET IO controller performance data / PROFINET communication / as PN IO c | No levice |
| product function / PROFINET IO controller performance data / PROFINET communication / as PN IO of product function / PROFINET IO device data volume • as user data for input variables / as PROFINET IO | No Jevice Yes |

| device / maximum | |
|---|---|
| as user data for input variables / for each sub- | 240 byte |
| module as PROFINET IO device | |
| as user data for output variables / for each sub- module as PROFINET IO device | 240 byte |
| as user data for the consistency area for each sub- module | 240 byte |
| number of submodules / per PROFINET IO-Device | 32 |
| performance data / telecontrol | |
| protocol / is supported | |
| • TCP/IP | Yes |
| product functions / management, configuration, engineeri | ng |
| product function / MIB support | Yes |
| protocol / is supported | |
| • SNMP v1 | Yes |
| • DCP | Yes |
| • LLDP | Yes |
| configuration software | |
| required | STEP 7 V5.4 or higher / STEP 7 Professional V11 (TIA Portal) or higher |
| identification & maintenance function | |
| I&M0 - device-specific information | Yes |
| I&M1 – higher level designation/location designation | Yes |
| product functions / diagnostics | |
| product function / web-based diagnostics | Yes |
| product functions / switch | |
| product feature / switch | Yes |
| product function | |
| switch-managed | No |
| with IRT / PROFINET IO switch | No |
| configuration with STEP 7 | Yes |
| product functions / redundancy | |
| product function | |
| ring redundancy | Yes |
| redundancy manager | No |
| protocol / is supported / Media Redundancy Protocol (MRP) | Yes |
| product functions / security | |
| product function | |
| password protection for Web applications | No |
| ACL - IP-based | |
| | Yes |
| ACL - IP-based for PLC/routing | Yes No |
| ACL - IP-based for PLC/routing switch-off of non-required services | |
| | No |
| switch-off of non-required services | No Yes |
| switch-off of non-required servicesblocking of communication via physical ports | No Yes Yes |
| switch-off of non-required services blocking of communication via physical ports log file for unauthorized access | No Yes Yes |
| switch-off of non-required services blocking of communication via physical ports log file for unauthorized access product functions / time | No Yes Yes No |
| switch-off of non-required services blocking of communication via physical ports log file for unauthorized access product functions / time product function / SICLOCK support | No Yes Yes No Yes |
| switch-off of non-required services blocking of communication via physical ports log file for unauthorized access product functions / time product function / SICLOCK support product function / pass on time synchronization | No Yes Yes No Yes |
| switch-off of non-required services blocking of communication via physical ports log file for unauthorized access product functions / time product function / SICLOCK support product function / pass on time synchronization protocol / is supported | No Yes Yes No Yes Yes |
| switch-off of non-required services blocking of communication via physical ports log file for unauthorized access product functions / time product function / SICLOCK support product function / pass on time synchronization protocol / is supported NTP | No Yes Yes No Yes Yes |
| switch-off of non-required services blocking of communication via physical ports log file for unauthorized access product functions / time product function / SICLOCK support product function / pass on time synchronization protocol / is supported NTP further information / internet-Links | No Yes Yes No Yes Yes |
| switch-off of non-required services blocking of communication via physical ports log file for unauthorized access product functions / time product function / SICLOCK support product function / pass on time synchronization protocol / is supported NTP further information / internet-Links Internet-Link | No Yes Yes Yes Yes |
| switch-off of non-required services blocking of communication via physical ports log file for unauthorized access product functions / time product function / SICLOCK support product function / pass on time synchronization protocol / is supported NTP further information / internet-Links Internet-Link to web page: selection aid TIA Selection Tool | No Yes Yes No Yes Yes Yes |
| switch-off of non-required services blocking of communication via physical ports log file for unauthorized access product functions / time product function / SICLOCK support product function / pass on time synchronization protocol / is supported NTP further information / internet-Links Internet-Link to web page: selection aid TIA Selection Tool to website: Industrial communication | No Yes Yes No Yes Yes Yes http://www.siemens.com/snst http://www.siemens.com/simatic-net |
| switch-off of non-required services blocking of communication via physical ports log file for unauthorized access product functions / time product function / SICLOCK support product function / pass on time synchronization protocol / is supported NTP further information / internet-Links Internet-Link to web page: selection aid TIA Selection Tool to website: Industrial communication to website: Industry Mall | No Yes Yes No Yes Yes Yes http://www.siemens.com/snst http://www.siemens.com/simatic-net http://www.siemens.com/simatic-net |
| switch-off of non-required services blocking of communication via physical ports log file for unauthorized access product functions / time product function / SICLOCK support product function / pass on time synchronization protocol / is supported NTP further information / internet-Links Internet-Link to web page: selection aid TIA Selection Tool to website: Industrial communication to website: Industry Mall to website: Information and Download Center | No Yes Yes No Yes Yes Yes http://www.siemens.com/snst http://www.siemens.com/sinatic-net http://www.siemens.com/sinatic-net http://www.siemens.com/sinatic-net |
| switch-off of non-required services blocking of communication via physical ports log file for unauthorized access product functions / time product function / SICLOCK support product function / pass on time synchronization protocol / is supported NTP further information / internet-Links Internet-Link to web page: selection aid TIA Selection Tool to website: Industrial communication to website: Industry Mall to website: Information and Download Center to website: Image database | No Yes Yes No Yes Yes Yes Yes http://www.siemens.com/snst http://www.siemens.com/simatic-net http://www.siemens.com/simatic-net http://www.siemens.com/simatic-net http://www.siemens.com/simatic-net http://www.siemens.com/simatic-net http://www.siemens.com/bilddb |
| switch-off of non-required services blocking of communication via physical ports log file for unauthorized access product functions / time product function / SICLOCK support product function / pass on time synchronization protocol / is supported NTP further information / internet-Links Internet-Link to web page: selection aid TIA Selection Tool to website: Industrial communication to website: Industry Mall to website: Information and Download Center to website: Image database to website: CAx-Download-Manager | No Yes Yes No Yes Yes Yes Yes http://www.siemens.com/snst http://www.siemens.com/simatic-net http://www.siemens.com/simatic-net http://www.siemens.com/industry/infocenter http://www.siemens.com/industry/infocenter http://automation.siemens.com/bilddb http://www.siemens.com/cax |
| switch-off of non-required services blocking of communication via physical ports log file for unauthorized access product functions / time product function / SICLOCK support product function / pass on time synchronization protocol / is supported NTP further information / internet-Links Internet-Link to web page: selection aid TIA Selection Tool to website: Industrial communication to website: Industry Mall to website: Information and Download Center to website: Image database to website: CAx-Download-Manager to website: Industry Online Support | No Yes Yes No Yes Yes Yes Yes http://www.siemens.com/snst http://www.siemens.com/simatic-net http://www.siemens.com/simatic-net http://www.siemens.com/industry/infocenter http://www.siemens.com/industry/infocenter http://automation.siemens.com/bilddb http://www.siemens.com/cax |

functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Third-party products that may be in use should also be considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit http://support.automation.siemens.com. (V3.4)

last modified:

8/3/2021 🖸