SIEMENS

Data sheet

6ES7314-1AG14-0AB0



SIMATIC S7-300, CPU 314 Central processing unit with MPI, Integr. power supply 24 V DC, work memory 128 KB, Micro Memory Card required

Figure simila

General information	
HW functional status	01
Firmware version	V3.3
Engineering with	
Programming package	STEP 7 V5.5 + SP1 or higher or STEP 7 V5.2 + SP1 or higher with HSP 218
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
external protection for power supply lines (recommendation)	2 A min.
Mains buffering	
 Mains/voltage failure stored energy time 	5 ms
 Repeat rate, min. 	1 s
Input current	
Current consumption (rated value)	650 mA
Current consumption (in no-load operation), typ.	140 mA
Inrush current, typ.	3.5 A
l²t	1 A ² ·s
Power loss	
Power loss, typ.	4 W
Memory	
Work memory	
• integrated	128 kbyte
expandable	No
Load memory	
Plug-in (MMC)	Yes
Plug-in (MMC), max.	8 Mbyte
 Data management on MMC (after last programming), min. 	10 y
Backup	
• present	Yes; Guaranteed by MMC (maintenance-free)
without battery	Yes; Program and data
CPU processing times	
for bit operations, typ.	0.06 μs
for word operations, typ.	0.12 μs
for fixed point arithmetic, typ.	0.16 µs

for floating point arithmetic, typ.	0.59 μs
CPU-blocks	- 1.00 μο
Number of blocks (total)	1 024; (DBs, FCs, FBs); the maximum number of loadable blocks can
	be reduced by the MMC used.
DB	4.004 N
Number, max.	1 024; Number range: 1 to 16000
• Size, max.	64 kbyte
FB	
Number, max.	1 024; Number range: 0 to 7999
• Size, max.	64 kbyte
FC Number was	4 004 Noveles and 20 45 7000
Number, max. Size may.	1 024; Number range: 0 to 7999
• Size, max.	64 kbyte
Number, max.	see instruction list
Size, max. Number of free evels ORs.	64 kbyte
Number of free cycle OBs Number of time clarm OBs	1; OB 1
Number of time alarm OBs	1; OB 10
Number of delay alarm OBs Number of explicit integrant OBs	2; OB 20, 21
Number of cyclic interrupt OBs	4; OB 32, 33, 34, 35
Number of process alarm OBs	1; OB 40
Number of startup OBs	1; OB 100
Number of asynchronous error OBs	4; OB 80, 82, 85, 87
Number of synchronous error OBs	2; OB 121, 122
Nesting depth	
 per priority class 	16
additional within an error OB	4
Counters, timers and their retentivity	
S7 counter	
Number	256
Retentivity	
— adjustable	Yes
— lower limit	0
— upper limit	255
— preset	Z 0 to Z 7
Counting range	
— lower limit	0
— upper limit	999
IEC counter	
• present	Yes
• Type	SFB
Number	Unlimited (limited only by RAM capacity)
S7 times	
Number	256
Retentivity	
— adjustable	Yes
— lower limit	0
— upper limit	255
— preset	No retentivity
Time range	
— lower limit	10 ms
— upper limit	9 990 s
IEC timer	
• present	Yes
• Type	SFB
Number	Unlimited (limited only by RAM capacity)
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	64 kbyte
Flag	
• Size, max.	256 byte
- OIEO, ITIOX	200 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0

Retentivity available	Yes; MB 0 to MB 255
Retentivity available Retentivity preset	MB 0 to MB 15
Number of clock memories	8; 1 memory byte
Data blocks	o, i memory byte
Retentivity adjustable	Yes; via non-retain property on DB
Retentivity preset	Yes
Local data	
per priority class, max.	32 kbyte; Max. 2 KB per block
Address area	
I/O address area	
• Inputs	1 024 byte
• Outputs	1 024 byte
Process image	
• Inputs	1 024 byte
Outputs	1 024 byte
Inputs, adjustable	1 024 byte
Outputs, adjustable	1 024 byte
Inputs, default	128 byte
Outputs, default	128 byte
Digital channels	
• Inputs	1 024
— of which central	1 024
Outputs	1 024
— of which central	1 024
Analog channels	
• Inputs	256
— of which central	256
Outputs	256
— of which central	256
Hardware configuration	
Hardware configuration	
Number of expansion units, max.	3
	3
Number of expansion units, max.	0
Number of expansion units, max. Number of DP masters	
Number of expansion units, max. Number of DP masters • integrated	0
Number of expansion units, max. Number of DP masters • integrated • via CP	0
Number of expansion units, max. Number of DP masters • integrated • via CP Number of operable FMs and CPs (recommended)	0 4
Number of expansion units, max. Number of DP masters • integrated • via CP Number of operable FMs and CPs (recommended) • FM	0 4 8
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP	0 4 8 8
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN	0 4 8 8
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN Rack Rack Racks, max. Modules per rack, max.	0 4 8 8 10
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN Rack Racks, max.	0 4 8 8 10
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN Rack Rack Racks, max. Modules per rack, max.	0 4 8 8 10
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN Rack Racks, max. Modules per rack, max.	0 4 8 8 10
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN Rack Rack Nacks, max. Modules per rack, max. Time of day Clock	0 4 8 8 8 10
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN Rack Rack Racks, max. Modules per rack, max. Time of day Clock Hardware clock (real-time)	0 4 8 8 10 4 8
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN Rack Rack Racks, max. Modules per rack, max. Itime of day Clock Hardware clock (real-time) retentive and synchronizable	0 4 8 8 10 4 8 Yes
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN Rack Racks, max. Modules per rack, max. Hodules per rack, max. Time of day Clock Hardware clock (real-time) retentive and synchronizable Backup time	0 4 8 8 10 4 8 Yes Yes Yes Yes 6 wk; At 40 °C ambient temperature
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN Rack Racks, max. Modules per rack, max. Modules per rack, max. Time of day Clock Hardware clock (real-time) retentive and synchronizable Backup time Deviation per day, max. Behavior of the clock following POWER-ON Behavior of the clock following expiry of backup	0 4 8 8 10 4 8 Yes Yes Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN Rack Rack Racks, max. Modules per rack, max. Modules per rack, max. Time of day Clock Hardware clock (real-time) retentive and synchronizable Backup time Deviation per day, max. Behavior of the clock following POWER-ON Behavior of the clock following expiry of backup period	0 4 8 8 10 4 8 Yes Yes Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues running after POWER OFF
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN Rack Racks, max. Modules per rack, max. Modules per rack, max. Itime of day Clock Hardware clock (real-time) retentive and synchronizable Backup time Deviation per day, max. Behavior of the clock following POWER-ON Behavior of the clock following expiry of backup period Operating hours counter	0 4 8 8 10 4 8 Yes Yes Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN Rack Racks, max. Modules per rack, max. Modules per rack, max. Ime of day Clock Hardware clock (real-time) retentive and synchronizable Backup time Deviation per day, max. Behavior of the clock following POWER-ON Behavior of the clock following expiry of backup period Operating hours counter Number	8 8 10 4 8 Yes Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN Rack Racks, max. Modules per rack, max. Modules per rack, max. Itime of day Clock Hardware clock (real-time) retentive and synchronizable Backup time Deviation per day, max. Behavior of the clock following POWER-ON Behavior of the clock following expiry of backup period Operating hours counter Number Number/Number range	8 8 10 Yes Yes Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN Rack Racks, max. Modules per rack, max. Modules per rack, max. Itime of day Clock Hardware clock (real-time) retentive and synchronizable Backup time Deviation per day, max. Behavior of the clock following POWER-ON Behavior of the clock following expiry of backup period Operating hours counter Number Number Range of values	8 8 10 4 8 Yes Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101)
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN Rack Racks, max. Modules per rack, max. Modules per rack, max. Itime of day Clock Hardware clock (real-time) retentive and synchronizable Backup time Deviation per day, max. Behavior of the clock following POWER-ON Behavior of the clock following expiry of backup period Operating hours counter Number Number/Number range Range of values Granularity	9 4 8 8 8 10 4 8 8 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN Rack Racks, max. Modules per rack, max. Modules per rack, max. Ime of day Clock Hardware clock (real-time) retentive and synchronizable Backup time Deviation per day, max. Behavior of the clock following POWER-ON Behavior of the clock following expiry of backup period Operating hours counter Number Number Range of values Granularity retentive	8 8 10 4 8 Yes Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101)
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN Rack Racks, max. Modules per rack, max. Modules per rack, max. Time of day Clock Hardware clock (real-time) retentive and synchronizable Backup time Deviation per day, max. Behavior of the clock following POWER-ON Behavior of the clock following expiry of backup period Operating hours counter Number Number Range of values Granularity retentive Clock synchronization	8 8 10 4 8 Yes Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h Yes; Must be restarted at each restart
Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN Rack Rack Racks, max. Modules per rack, max. Modules per rack, max. Firme of day Clock Hardware clock (real-time) retentive and synchronizable Backup time Deviation per day, max. Behavior of the clock following POWER-ON Behavior of the clock following expiry of backup period Operating hours counter Number Range of values Granularity retentive Clock synchronization supported	8 8 10 4 8 Yes Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h Yes; Must be restarted at each restart Yes
Number of expansion units, max. Number of DP masters integrated via CP Number of operable FMs and CPs (recommended) FM CP, PtP CP, LAN Rack Racks, max. Modules per rack, max. Modules per rack, max. Time of day Clock Hardware clock (real-time) retentive and synchronizable Backup time Deviation per day, max. Behavior of the clock following POWER-ON Behavior of the clock following expiry of backup period Operating hours counter Number Number Range of values Granularity retentive Clock synchronization	8 8 10 4 8 Yes Yes 6 wk; At 40 °C ambient temperature 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h Yes; Must be restarted at each restart

● in AS, master	Yes
• in AS, slave	No
Digital inputs	
Number of digital inputs	0
Digital outputs	
	0
Number of digital outputs	0
Analog inputs	
Number of analog inputs	0
Analog outputs	
Number of analog outputs	0
Interfaces	
Number of industrial Ethernet interfaces	0
Number of PROFINET interfaces	0
Number of RS 485 interfaces	1; MPI
Number of RS 422 interfaces	0
1. Interface	
Interface type	Integrated RS 485 interface
Isolated	No
Interface types	
• RS 485	Yes
Output current of the interface, max.	200 mA
Protocols	V
• MPI	Yes
PROFIBUS DP master	No
PROFIBUS DP slave Print to a pint appearing.	No
Point-to-point connection	No
MPI	187.5 kbit/s
Transmission rate, max. Services	107.3 AUIUS
— PG/OP communication	Yes
— PG/OP communication — Routing	No
Global data communication	Yes
S7 basic communication	Yes
— S7 communication	Yes; Only server, configured on one side
— S7 communication, as client	No
— S7 communication, as server	Yes
Protocols	
PROFIsafe	No
communication functions / header	110
	Yes
PG/OP communication	Yes No
Data record routing Global data communication	110
supported	Yes
Number of GD loops, max.	8
Number of GD packets, max.	8
Number of GD packets, frank. Number of GD packets, transmitter, max.	8
Number of GD packets, transmitter, max. Number of GD packets, receiver, max.	8
Size of GD packets, max.	22 byte
Size of GD packet (of which consistent), max.	22 byte
S7 basic communication	
• supported	Yes
User data per job, max.	76 byte
 User data per job (of which consistent), max. 	76 byte; 76 bytes (with X_SEND or X_RCV); 64 bytes (with X_PUT or
	X_GET as server)
S7 communication	
supported	Yes
as server	Yes
as client	Yes; Via CP and loadable FB
User data per job, max.	180 byte; With PUT/GET

 User data per job (of which consistent), max. 	240 byte; as server
S5 compatible communication	
• supported	Yes; via CP and loadable FC
Number of connections	
• overall	12
usable for PG communication	11
— reserved for PG communication	1
 adjustable for PG communication, min. 	1
 adjustable for PG communication, max. 	11
 usable for OP communication 	11
 reserved for OP communication 	1
 adjustable for OP communication, min. 	1
 adjustable for OP communication, max. 	11
 usable for S7 basic communication 	8
 reserved for S7 basic communication 	0
 adjustable for S7 basic communication, min. 	0
— adjustable for S7 basic communication, max.	8
S7 message functions	
Number of login stations for message functions, max.	12; Depending on the configured connections for PG/OP and S7 basic communication
Process diagnostic messages	Yes
simultaneously active Alarm-S blocks, max.	300
Test commissioning functions	
Status block	Yes; Up to 2 simultaneously
Single step	Yes
Number of breakpoints	4
Status/control	
Status/control variable	Yes
Variables	Inputs, outputs, memory bits, DB, times, counters
 Number of variables, max. 	30
— of which status variables, max.	30
— of which control variables, max.	14
Forcing	v
• Forcing	Yes
Forcing, variables	Inputs, outputs
Number of variables, max. Diagnostic buffer.	10
Diagnostic buffer	Voc
presentNumber of entries, max.	Yes 500
•	500 No
— adjustable — of which powerfail-proof	
— of which powerfail-proofNumber of entries readable in RUN, max.	100; Only the last 100 entries are retained 499
adjustable	Yes; From 10 to 499
— aujustable — preset	10
Service data	10
• can be read out	Yes
Ambient conditions	
Ambient temperature during operation	
Minimum min. min.	0 °C
• max.	60 °C
configuration / header	
Configuration 7 fleader Configuration software	
STEP 7	Yes; V5.2 SP1 or higher with HW update
configuration / programming / header	165, V.S.Z. OF FOILINGHER WILLTTIVY apaale
Command set	see instruction list
Nesting levels	8
System functions (SFC)	o see instruction list
System functions (SFC) System function blocks (SFB)	see instruction list
Programming language	occ mod dodon not
— LAD	Yes

— FBD	Yes
— STL	Yes
— SCL	Yes
— CFC	Yes
— GRAPH	Yes
— HiGraph®	Yes
Know-how protection	
 User program protection/password protection 	Yes
 Block encryption 	Yes; With S7 block Privacy
Dimensions	
Width	40 mm
Height	125 mm
Depth	130 mm
Depth Weights	130 mm
	130 mm 280 g

last modified: 8/24/2021 **C**