Data sheet 6ES7416-5HS06-0AB0



SIMATIC S7-400H, CPU 416-5H, central processing unit for S7-400H and S7-400F/FH, 5 interfaces: 1x MPI/DP, 1x DP, 1x PN and 2 for sync modules, 16 MB memory (10 MB data/6 MB program)

General information	
Product type designation	CPU 416-5H PN/DP
HW functional status	1
Firmware version	V6.0
Product function	
Isochronous mode	No
Engineering with	
 Programming package 	As of STEP 7 V5.5 SP2 with HF1
CiR - Configuration in RUN	
CiR synchronization time, basic load	100 ms
CiR synchronization time, time per I/O byte	0 μs
Supply voltage	
Rated value (DC)	Power supply via system power supply
Input current	
from backplane bus 5 V DC, typ.	1.6 A
from backplane bus 5 V DC, max.	1.9 A
from backplane bus 24 V DC, max.	150 mA; 150 mA per DP interface
from interface 5 V DC, max.	90 mA; At each DP interface
Power loss	
Power loss, typ.	7.5 W
Memory	
Type of memory	RAM
Work memory	
integrated	16 Mbyte
integrated (for program)	6 Mbyte
integrated (for data)	10 Mbyte
expandable	No
Load memory	
 expandable FEPROM 	Yes; with Memory Card (FLASH)
 expandable FEPROM, max. 	64 Mbyte
integrated RAM, max.	1 Mbyte
• expandable RAM	Yes
expandable RAM, max.	64 Mbyte
Backup	
• present	Yes
with battery	Yes; all data
without battery	No
Battery	
Backup battery	

Backup current, max.	1 000 μΑ
Backup time, max.	Dealt with in the module data manual with the secondary conditions and the factors of influence
 Feeding of external backup voltage to CPU 	5 V DC to 15 V DC
CPU processing times	0 0 00 10 0 00
for bit operations, typ.	12.5 ns
for word operations, typ.	12.5 ns
for fixed point arithmetic, typ.	12.5 ns
for floating point arithmetic, typ.	25 ns
CPU-blocks	20.10
DB	
Number, max.	16 000; Number range: 1 to 16000
• Size, max.	64 kbyte
FB	
Number, max.	8 000; Number range: 0 to 7999
• Size, max.	64 kbyte
FC	
Number, max.	8 000; Number range: 0 to 7999
• Size, max.	64 kbyte
OB	
Number, max.	see instruction list
• Size, max.	64 kbyte
 Number of free cycle OBs 	1; OB 1
 Number of time alarm OBs 	8; OB 10-17
 Number of delay alarm OBs 	4; OB 20-23
 Number of cyclic interrupt OBs 	9; OB 30-38
 Number of process alarm OBs 	8; OB 40-47
 Number of DPV1 alarm OBs 	3; OB 55-57
 Number of startup OBs 	2; OB 100, 102
 Number of asynchronous error OBs 	9; OB 80-88
Number of synchronous error OBs	2; OB 121, 122
Nesting depth	
• per priority class	24
additional within an error OB	2
Counters, timers and their retentivity	
S7 counter	
• Number	2 048
Retentivity	V
— adjustable	Yes
— lower limit	0
— upper limit	2 047
— preset Counting range	Z 0 to Z 7
Journing range	
	0
— lower limit	0 999
— lower limit — upper limit	0 999
— lower limit — upper limit IEC counter	
— lower limit — upper limit IEC counter • present	999
— lower limit — upper limit IEC counter	999 Yes
 — lower limit — upper limit IEC counter • present • Type 	999 Yes SFB
 — lower limit — upper limit IEC counter • present • Type • Number 	999 Yes SFB
 — lower limit — upper limit IEC counter • present • Type • Number S7 times 	Yes SFB Unlimited (limited only by RAM capacity)
 — lower limit — upper limit IEC counter • present • Type • Number S7 times • Number 	Yes SFB Unlimited (limited only by RAM capacity)
 — lower limit — upper limit IEC counter • present • Type • Number S7 times • Number Retentivity 	Yes SFB Unlimited (limited only by RAM capacity) 2 048
 — lower limit — upper limit IEC counter • present • Type • Number S7 times • Number Retentivity — adjustable 	Yes SFB Unlimited (limited only by RAM capacity) 2 048 Yes
 — lower limit — upper limit IEC counter • present • Type • Number S7 times • Number Retentivity — adjustable — lower limit 	Yes SFB Unlimited (limited only by RAM capacity) 2 048 Yes 0
- lower limit - upper limit IEC counter • present • Type • Number S7 times • Number Retentivity - adjustable - lower limit - upper limit	Yes SFB Unlimited (limited only by RAM capacity) 2 048 Yes 0 2 047
- lower limit - upper limit IEC counter • present • Type • Number S7 times • Number Retentivity - adjustable - lower limit - upper limit - preset	Yes SFB Unlimited (limited only by RAM capacity) 2 048 Yes 0 2 047
- lower limit - upper limit IEC counter • present • Type • Number S7 times • Number Retentivity - adjustable - lower limit - upper limit - preset Time range	Yes SFB Unlimited (limited only by RAM capacity) 2 048 Yes 0 2 047 No times retentive
- lower limit - upper limit IEC counter • present • Type • Number S7 times • Number Retentivity - adjustable - lower limit - upper limit - preset Time range - lower limit	999 Yes SFB Unlimited (limited only by RAM capacity) 2 048 Yes 0 2 047 No times retentive

Number Number Control teachers and their retentivity Retentive data area fired times, counters, flags), max. Retentive data area fired times, counters, flags), max. Retentively available Retentively available Retentively preset All to 184 byte Retentively preset Retentively p	• Type	SFB
Retentive data area (ind. timers, counters, flags), max. Flore data (ind. timers) Flore		
Reterribre data area (incl. timers, counters, flags), max. Total working and load memory (with backup battery)		Chiminod (minod only by 10 an outputity)
Flag Size, max Federativity preset Mis 16 384 byte Retentivity preset Mis 10 to Mis 15 Number of Lock memories Mis 10 to Mis 15 Number of Lock memories Mis 10 to Mis 15 Number of Lock memories Mis 10 to Mis 15 Number of Lock memories Mis 10 to Mis 15 Number of Lock memories Mis 10 to Mis 15 Number of Lock memories Mis 10 to Mis 15 Number of Lock memories Mis 10 to Mis 15 Number of Lock memories Mis 10 to Mis 10		Total working and load memory (with backup battery)
1924 byte		Total Horning and load monory (War backap backery)
Retentivity preset Retentivity Ret	-	16 384 byte
Relativity preset Number of clock memories Relativity preset Address area Outputs		
Number of clock memories	•	MB 0 to MB 15
Address area	• •	8; in 1 memory byte
Address area	Local data	
Address area ID address area Inputs 16 kbyte 1	adjustable, max.	64 kbyte
Figure F	• preset	32 kbyte
• Inputs	Address area	
	I/O address area	
Process image	• Inputs	16 kbyte
Inputs, adjustable 16 kbyte	Outputs	16 kbyte
Outputs, adjustable inputs, default inputs	Process image	
Inputs, default Outputs, default Outputs, default Outputs, default Outputs, default Outputs Outp	 Inputs, adjustable 	16 kbyte
Outputs, default	 Outputs, adjustable 	16 kbyte
Consistent data, max. Access to consistent data in process image Subprocess images Number of subprocess images, max. Inputs Inputs Outputs Ou	 Inputs, default 	1 024 byte
Access to consistent data in process image Number of subprocess images, max. Is Digital channels Inputs Outputs Outputs Inputs	Outputs, default	1 024 byte
Subprocess images Number of subprocess images, max. Is Inputs	• consistent data, max.	244 byte
Number of subprocess images, max. Digital channels	Access to consistent data in process image	Yes
Inputs	Subprocess images	
Inputs		15
Outputs 131 072 Outputs 131 072 Analog channels Inputs 8 192 Outputs 8 192 Hardware configuration Number of expansion units, max. 21 connectable OPs 95 Multicomputing No Interface modules Number of connectable IM 460s, max. 6 Number of connectable IM 460s, max. 4; Single mode only Number of DP masters integrated 2 via CP 10; CP 443-5 Extended No Number of IC Controllers integrated 0 via CP 10; CP 443-5 Extended No via interface module 0 Number of IC Controllers integrated 1 via CP 0 No Number of IC Controllers integrated 1 via CP 0 No Number of IC Controllers integrated 1 via CP 0 No See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master Stots required slots 2 Time of day	Digital channels	
Outputs		
Analog channels Inputs 8 192 — of which central 8 192 — Outputs 8 192 — of which central 8 192 — Outputs 8 192 — of which central 8 192 — of which central 8 192 — of which central 8 192 — the provided of expansion units, max. 21 connectable OPs 95 Multicomputing No Interface modules • Number of connectable IMs (total), max. 6 • Number of connectable IMs (total), max. 6 • Number of connectable IM 460s, max. 4; Single mode only Number of DP masters • integrated 2 • via CP 10; CP 443-5 Extended • via interface module No • via interface module 1D 0 Number of IO Controllers • integrated 1 • via CP 0 Number of Operable FMs and CPs (recommended) • FM See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections • PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master Time of day	— of which central	
Analog channels	·	
Inputs		131 072
- of which central 8 192 Outputs 8 192 - of which central 8 192 - of which central 8 192 Hardware configuration Number of expansion units, max. 21 connectable OPs 95 Multicomputing No Interface modules • Number of connectable IMs (total), max. 6 • Number of connectable IM 460s, max. 4; Single mode only Number of DP masters • integrated 2 • via CP 10; CP 443-5 Extended • via interface module 0 Number of IO Controllers • integrated 0 • wia interface module 0 Number of IO Controllers • integrated 1 • via CP 0 Number of IO Controllers • integrated 1 • via CP 0 Number of IO Controllers • integrated 1 • via CP 0 Number of operable FMs and CPs (recommended) • FM See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections • CP, PtP See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections • PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master Slots • required slots 2 Time of day		0.400
Outputs 8 192 — of which central 8 192 Hardware configuration Number of expansion units, max. 21 connectable OPs 95 Multicomputing No Interface modules • Number of connectable IM 460s, max. 6 • Number of connectable IM 460s, max. 4; Single mode only Number of DP masters • integrated 2 • via CP 10; CP 443-5 Extended • via interface module 0 Number of IO Controllers • integrated 1 • via CP 0 • Mixed mode IM + CP permitted No • via interface module 0 Number of IO Controllers • integrated 1 • via CP 0 Number of operable FMs and CPs (recommended) • FM See manual Automation System 57-400H fault-tolerant systems. Limited by number of slots and number of connections • PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master • required slots 2 Itme of day	·	
Hardware configuration Number of expansion units, max. 21 connectable OPs 95 Multicomputing Interface modules • Number of connectable IMs (total), max. • Number of connectable IM 460s, max. • Number of connectable IM 463s, max. • Number of connectable IM 463s, max. • Number of DP masters • integrated • via CP • Mixed mode IM + CP permitted • via interface module • Mixed mode IM + CP permitted • via interface module • Integrated • via CP • Mixed mode IM + CP permitted • via interface module • Number of ID controllers • integrated • via CP • O Number of operable FMs and CPs (recommended) • FM • See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections • PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master Time of day		
Hardware configuration Number of expansion units, max. connectable OPs Multicomputing Interface modules • Number of connectable IMs (total), max. • Number of connectable IM 460s, max. • Number of connectable IM 460s, max. • Number of DP masters • integrated • via CP • Mixed mode IM + CP permitted • via interface module Number of IO Controllers • integrated • via CP • Mixed mode IM + CP permitted • via CP Number of IO Controllers • integrated • via CP Number of operable FMs and CPs (recommended) • FM See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections • PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master	·	
Number of expansion units, max. connectable OPs Multicomputing Interface modules • Number of connectable IMs (total), max. • Number of connectable IM 460s, max. • Number of connectable IM 463s, max. • Number of DP masters • integrated • via CP • Mixed mode IM + CP permitted • via interface module Number of IO Controllers • integrated • via CP Number of IO Controllers • integrated • via CP Number of operable FMs and CPs (recommended) • FM See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections • PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master		0 192
connectable OPs Multicomputing No Interface modules Number of connectable IMs (total), max. Number of connectable IM 460s, max. Number of connectable IM 460s, max. Single mode only Number of DP masters integrated via CP Mixed mode IM + CP permitted No via interface module Number of IO Controllers integrated Via CP Number of IO Controllers FM See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master It integrated PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master		21
Multicomputing No Interface modules • Number of connectable IMs (total), max. • Number of connectable IM 460s, max. • Number of connectable IM 463s, max. • Number of pressures • integrated • via CP • Mixed mode IM + CP permitted • via interface module No • via interface module Number of IO Controllers • integrated • via CP Onumber of operable FMs and CPs (recommended) • FM See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections • CP, PtP See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections • PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master Slots • required slots 2 Time of day		
Interface modules • Number of connectable IMs (total), max. • Number of connectable IM 460s, max. • Number of connectable IM 463s, max. • Number of DP masters • integrated • via CP • Mixed mode IM + CP permitted • via interface module Number of IO Controllers • integrated • via CP • Mixed mode IM + CP permitted • Via interface module Number of IO Controllers • integrated • via CP Number of operable FMs and CPs (recommended) • FM See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections • CP, PtP See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections • PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master Slots • required slots 2 Time of day		
Number of connectable IMs (total), max. Number of connectable IM 460s, max. Number of DP masters integrated via CP Mixed mode IM + CP permitted via interface module Number of IO Controllers integrated via CP ON Number of IO Controllers integrated via CP Number of IO Controllers integrated via CP Number of JO Controllers integrated via CP Number of operable FMs and CPs (recommended) FM See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master Slots required slots 2 Time of day		110
Number of connectable IM 460s, max. Number of DP masters integrated via CP Mixed mode IM + CP permitted via interface module Number of IO Controllers integrated via CP ONUMBER of Operable FMs and CPs (recommended) FM See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master Number of day Number of day		6
Number of DP masters integrated via CP Mixed mode IM + CP permitted via integrated via CP Number of IO Controllers integrated via CP Number of operable FMs and CPs (recommended) FM See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections PROFIBUS and Ethernet CPs Slots required slots 2 Time of day		
Number of DP masters integrated via CP Mixed mode IM + CP permitted No via interface module Number of IO Controllers integrated via CP Number of operable FMs and CPs (recommended) FM See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections CP, PtP See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master Slots required slots 2 Time of day	•	
via CP Mixed mode IM + CP permitted via interface module via interface module Number of IO Controllers integrated via CP Number of operable FMs and CPs (recommended) FM See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections CP, PtP See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master Time of day		
 Mixed mode IM + CP permitted via interface module No Number of IO Controllers integrated via CP Number of operable FMs and CPs (recommended) FM See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections CP, PtP See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master Slots required slots 2 Time of day	integrated	2
 Mixed mode IM + CP permitted via interface module No Number of IO Controllers integrated via CP Number of operable FMs and CPs (recommended) FM See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections CP, PtP See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master Slots required slots 2 Time of day	-	
via interface module Number of IO Controllers integrated via CP 0 Number of operable FMs and CPs (recommended) FM See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections CP, PtP See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master Slots required slots 2 Time of day		
Number of IO Controllers • integrated • via CP 0 Number of operable FMs and CPs (recommended) • FM • CP, PtP • CP, PtP • PROFIBUS and Ethernet CPs • required slots • required slots • integrated 1 0 See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections • PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master 2 Time of day	•	
 integrated via CP Number of operable FMs and CPs (recommended) FM See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections CP, PtP See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections PROFIBUS and Ethernet CPs Slots required slots Time of day 	Number of IO Controllers	
Number of operable FMs and CPs (recommended) • FM See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections • CP, PtP See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections • PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master Slots • required slots 2 Time of day		1
See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections CP, PtP See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master Slots required slots 2 Time of day	• via CP	0
number of slots and number of connections See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master Slots required slots 2 Time of day	Number of operable FMs and CPs (recommended)	
See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master Slots required slots 2 Time of day	• FM	See manual Automation System S7-400H fault-tolerant systems. Limited by
number of slots and number of connections • PROFIBUS and Ethernet CPs 14; Of which max. 10 CP as DP master Slots • required slots 2 Time of day		
● PROFIBUS and Ethernet CPs Slots ● required slots 2 Time of day	• CP, PtP	
Slots	PROFIBLIS and Ethernet CPs	
• required slots 2 Time of day		THE OF WHICH HIGH. TO OF AS DE HIGSTOR
Time of day		2
	·	

 S7 communication, as server 	Yes
— Equidistance	No
— Isochronous mode	No
— SYNC/FREEZE	No
Activation/deactivation of DP slaves	No
 Direct data exchange (slave-to-slave communication) 	No
— DPV1	Yes
Address area	100
— Inputs, max.	2 kbyte
— Outputs, max.	2 kbyte
User data per DP slave	·
— User data per DP slave, max.	244 byte
— Inputs, max.	244 byte
— Outputs, max.	244 byte
— Slots, max.	244
— per slot, max.	128 byte
PROFIBUS DP slave	
Number of connections	No configuration of CPU as DP slave
2. Interface	
Interface type	PROFINET
Isolated	Yes
automatic detection of transmission rate	Yes; Autosensing
Autonegotiation	Yes
Autocrossing	Yes
Change of IP address at runtime, supported	No
Number of connection resources	96
Interface types	
• RJ 45 (Ethernet)	Yes
 Number of ports 	2
integrated switch	Yes
Protocols	
PROFINET IO Controller	Yes
PROFINET IO Device	No
PROFINET CBA	No
PROFIBUS DP master	No
PROFIBUS DP slave	No
Open IE communication	Yes
Web server	No
Point-to-point connection	No
Media redundancy	Yes
PROFINET IO Controller	400 M %
Transmission rate, max.	100 Mbit/s
Services	Voc
— PG/OP communication	Yes
— S7 communication	Yes
— Isochronous mode	No Voc: Single made only
— Shared device	Yes; Single mode only
— Prioritized startup	No
Number of connectable IO Devices, max.	256; In redundant mode via both interfaces 256
— Number of connectable IO Devices for RT, max.— of which in line, max.	256
Of which in line, max. Activation/deactivation of IO Devices	No
— Activation/deactivation of IO Devices — IO Devices changing during operation (partner)	No
ports), supported	NO
Device replacement without swap medium	Yes
— Send cycles	250 μs, 500 μs, 1 ms, 2 ms, 4 ms
— Updating time	250 µs to 512 ms, minimum value depends on the number of configured user
A.I.I.	data and the configured single or redundant mode
Address area	Olibuda
— Inputs, max.	8 kbyte
— Outputs, max.	8 kbyte

Lloor data consistency (1999)	1 024 byto
User data consistency, max. Open IE communication	1 024 byte
Number of connections, max.	94
Local port numbers used at the system end	0, 20, 21, 25, 102, 135, 161, 34962, 34963, 34964, 65532, 65533, 65534, 65535
 Keep-alive function, supported 	Yes
3. Interface	
Interface type	PROFIBUS DP
Number of connection resources	32
Interface types	
• RS 485	Yes
 Output current of the interface, max. 	150 mA
Protocols	
 PROFIBUS DP master 	Yes
PROFIBUS DP slave	No
PROFIBUS DP master	
 Number of connections, max. 	32
 Transmission rate, max. 	12 Mbit/s
 Number of DP slaves, max. 	125
Services	
— PG/OP communication	Yes
— Routing	Yes
 Global data communication 	No
 — S7 basic communication 	No
— S7 communication	Yes
 S7 communication, as client 	Yes
 S7 communication, as server 	Yes
— Equidistance	No
 Isochronous mode 	No
— SYNC/FREEZE	No
 Activation/deactivation of DP slaves 	No
 Direct data exchange (slave-to-slave communication) 	No
— DPV0	Yes
— DPV1	Yes
Address area	
— Inputs, max.	8 kbyte
— Outputs, max.	8 kbyte
User data per DP slave	OAA butu
— User data per DP slave, max.	244 byte
— Inputs, max. — Outputs, max.	244 byte
• •	244 byte
— Slots, max. — per slot, max.	244 128 byte
— per slot, max. 4. Interface	120 Dyle
Interface type	Pluggable synchronization submodule (FO)
Plug-in interface modules	Synchronization modules 6ES7960-1AA06-0XA0 or 6ES7960-1AB06-0XA0
5. Interface	Synthia in Education in Education of the Control of the Education in Education
Interface type	Pluggable synchronization submodule (FO)
Plug-in interface modules	Synchronization modules 6ES7960-1AA06-0XA0 or 6ES7960-1AB06-0XA0
Protocols	,
Redundancy mode	
Media redundancy	
Switchover time on line break, typ.	200 ms
Number of stations in the ring, max.	50
SIMATIC communication	
S7 routing	Yes
Open IE communication	
• TCP/IP	Yes; via integrated PROFINET interface and loadable FBs
 Number of connections, max. 	94
— Data length, max.	32 kbyte
*	

 several passive connections per port, supported 	Yes
• ISO-on-TCP (RFC1006)	Yes; Via integrated PROFINET interface or CP 443-1 and loadable FBs
 Number of connections, max. 	94
— Data length, max.	32 kbyte; 1 452 bytes via CP 443-1 Adv.
• UDP	Yes; via integrated PROFINET interface and loadable FBs
 Number of connections, max. 	94
— Data length, max.	1 472 byte
Web server	
• supported	No
Isochronous mode	
Equidistance	No
communication functions / header	
PG/OP communication	Yes
 Number of connectable OPs without message processing 	95
 Number of connectable OPs with message processing 	95; When using Alarm_S/SQ and Alarm_D/DQ
Data record routing	Yes
Global data communication	
• supported	No
S7 basic communication	
communication function / S7 basic communication	No
S7 communication	
• supported	Yes
• as server	Yes
• as client	Yes
User data per job, max.	64 kbyte
 User data per job (of which consistent), max. 	462 byte; 1 variable
S5 compatible communication	
supported	Yes; (via CP max. 10 and FC AG_SEND and FC AG_RECV)
User data per job, max.	8 kbyte
 User data per job (of which consistent), max. 	240 byte
Number of simultaneous AG-SEND/AG-RECV orders per	64/64
CPU, max.	
Standard communication (FMS)	
• supported	Yes; Via CP and loadable FB
Number of connections	
• overall	96
 usable for PG communication 	
 reserved for PG communication 	1
 adjustable for PG communication, max. 	0
 usable for OP communication 	
 reserved for OP communication 	1
 adjustable for OP communication, max. 	0
 usable for S7 basic communication 	
 reserved for S7 basic communication 	0
 adjustable for S7 basic communication, max. 	0
 usable for S7 communication 	
 reserved for S7 communication 	0
 adjustable for S7 communication, max. 	0
 usable for routing 	
— reserved for routing	0
— adjustable for routing, max.	0
S7 message functions	
Number of login stations for message functions, max.	95; Max. 95 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 16 with Alarm, Alarm_8, Alarm_8P, Notify and Notify_8 (e.g. WinCC)
Symbol-related messages	No
SCAN procedure	No
Program alarms	Yes
Process diagnostic messages	Yes
simultaneously active Alarm-S blocks, max.	1 000; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks
Alarm 8-blocks	Yes
 Number of instances for alarm 8 and S7 communication 	10 000

blocks, max.	
• preset, max.	1 200
Process control messages	Yes
Number of archives that can log on simultaneously (SFB 37 AR_SEND)	64
Test commissioning functions	
Status block	Yes
Single step	Yes
Number of breakpoints	16
Status/control	
 Status/control variable 	Yes; Up to 16 variable tables
 Variables 	Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
Number of variables, max.	70
Forcing	
Forcing	Yes
 Forcing, variables 	Inputs/outputs, bit memories, distributed I/Os
Number of variables, max.	512
Diagnostic buffer	
• present	Yes
 Number of entries, max. 	3 200
— adjustable	Yes
— preset	120
Service data	
• can be read out	Yes
EMC	
Emission of radio interference acc. to EN 55 011	
 Limit class A, for use in industrial areas 	Yes
 Limit class B, for use in residential areas 	No
configuration / header	
Configuration software	
• STEP 7	Yes
configuration / programming / header	
 Command set 	see instruction list
Nesting levels	7
~	
Access to consistent data in process image	Yes
-	
Access to consistent data in process image	Yes
Access to consistent data in process imageSystem functions (SFC)	Yes see instruction list
 Access to consistent data in process image System functions (SFC) System function blocks (SFB) 	Yes see instruction list
 Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language 	Yes see instruction list see instruction list
 Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD 	Yes see instruction list see instruction list Yes
 Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD 	Yes see instruction list see instruction list Yes Yes
 Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL 	Yes see instruction list see instruction list Yes Yes Yes
 Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL 	Yes see instruction list see instruction list Yes Yes Yes Yes Yes
 Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC 	Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes
 Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH 	Yes see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
 Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® 	Yes see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously actives	Yes see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active	Yes see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active RD_REC WR_REC	Yes see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active — RD_REC WR_REC WR_PARM	Yes see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active RD_REC WR_REC WR_PARM PARM_MOD	Yes see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active RD_REC WR_REC WR_PARM PARM_MOD WR_DPARM	Yes see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active RD_REC WR_REC WR_PARM PARM_MOD WR_DPARM DPNRM_DG	Yes see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active RD_REC WR_REC WR_PARM PARM_MOD WR_DPARM DPNRM_DG RDSYSST	Yes see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active RD_REC WR_REC WR_PARM PARM PARM_MOD WR_DPARM DPNRM_DG RDSYSST DP_TOPOL	Yes see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active RD_REC WR_REC WR_PARM PARM_MOD WR_DPARM DPNRM_DG RDSYSST DP_TOPOL configuration / programming / number of simultaneously active	Yes see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
 Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language — LAD — FBD — STL — SCL — CFC — GRAPH — HiGraph® configuration / programming / number of simultaneously active — RD_REC — WR_REC — WR_PARM — PARM_MOD — WR_DPARM — DPNRM_DG — RDSYSST — DP_TOPOL configuration / programming / number of simultaneously active — RDSYSST — DP_TOPOL configuration / programming / number of simultaneously active — RDREC 	Yes see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active RD_REC WR_REC WR_PARM PARM_MOD WR_DPARM DPNRM_DG RDSYSST DP_TOPOL configuration / programming / number of simultaneously active RDSYSST RDSYSST RDP_TOPOL configuration / programming / number of simultaneously active RDREC WRREC	Yes see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active RD_REC WR_REC WR_PARM PARM_MOD WR_DPARM DPNRM_DG RDSYSST DP_TOPOL configuration / programming / number of simultaneously active RDSYSST RDSYSST RDP_TOPOL CONFIGURATION / programming / number of simultaneously active RDREC WRREC	Yes see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye

Width	50 mm
Height	290 mm
Depth	219 mm
Weights	
Weight, approx.	995 g

last modified: 9/7/2023 🖸