



SIMATIC S7-1500, CPU Bundle consisting of: CPU 1518-4 PN/DP MFP (6ES7518-4AX00-1AB0), including C/C++ Runtime and OPC UA Runtime license, 6 MB work memory for program and 60 MB for data, 1st interface: PROFINET IRT with 2-port switch, 2nd interface: PROFINET RT, 3rd interface: PROFINET basic services, 4th interface: PROFIBUS, 1 ns bit performance, SIMATIC Memory Card (min. 2 GB) required

| General information  |   |
|--|---|
| Product type designation   | CPU 1518-4 PN/DP MFP  |
| HW functional status   | FS04  |
| Firmware version   | V3.0  |
| Product function   |   |
| <ul style="list-style-type: none"> <li>I&amp;M data</li> </ul>   | Yes; I&M0 to I&M3   |
| <ul style="list-style-type: none"> <li>Isochronous mode</li> </ul>                                       | Yes; Distributed and central; with minimum OB 6x cycle of 125 µs (distributed) and 1 ms (central) |
| Engineering with   |   |
| <ul style="list-style-type: none"> <li>STEP 7 TIA Portal configurable/integrated from version</li> </ul> | V18 (FW V3.0); V15 (FW V2.5) or higher  |
| Configuration control  |   |
| via dataset  | Yes   |
| Display  |   |
| Screen diagonal [cm]   | 6.1 cm  |
| Control elements   |   |
| Number of keys   | 6   |
| Mode selector switch   | 1   |
| Supply voltage   |   |
| Rated value (DC)   | 24 V  |
| permissible range, lower limit (DC)  | 19.2 V  |
| permissible range, upper limit (DC)  | 28.8 V  |
| Reverse polarity protection  | Yes   |
| Mains buffering  |   |
| <ul style="list-style-type: none"> <li>Mains/voltage failure stored energy time</li> </ul>               | 5 ms  |
| <ul style="list-style-type: none"> <li>Repeat rate, min.</li> </ul>                                      | 1/s   |
| Input current  |   |
| Current consumption (rated value)  | 1.7 A   |
| Current consumption, max.  | 2 A   |
| Inrush current, max.   | 2 A; Rated value  |
| I <sup>2</sup> t   | 0.4 A <sup>2</sup> ·s   |
| Power  |   |
| Infeed power to the backplane bus  | 12 W  |
| Power consumption from the backplane bus (balanced)  | 35 W  |
| Power loss   |   |
| Power loss, typ.   | 29 W  |
| Memory   |   |
| Number of slots for SIMATIC memory card  | 1   |
| SIMATIC memory card required   | Yes   |
| Work memory  |   |
| <ul style="list-style-type: none"> <li>integrated (for program)</li> </ul>                               | 6 Mbyte   |

|  |   |
|--|---|
| <ul style="list-style-type: none"> <li>integrated (for data)</li> <li>integrated (for CPU function library of CPU Runtime)</li> </ul>  | 60 Mbyte<br>50 Mbyte; Note: The "CPU function library of the CPU" are C/C++ blocks for the user program that were created using the SIMATIC ODK 1500S or Target 1500S.  |
| <b>Working memory for additional functions</b>   |   |
| <ul style="list-style-type: none"> <li>Integrated (for C/C++ Runtime application)</li> <li>available (for Linux runtime application)</li> </ul>  | 1 024 Mbyte<br>1 Gbyte  |
| <b>Load memory</b>   |   |
| <ul style="list-style-type: none"> <li>Plug-in (SIMATIC Memory Card), max.</li> </ul>  | 32 Gbyte; the memory card must have at least 2 GB of space on it  |
| <b>Backup</b>  |   |
| <ul style="list-style-type: none"> <li>maintenance-free</li> </ul>   | Yes   |
| <b>CPU processing times</b>  |   |
| for bit operations, typ.   | 1 ns  |
| for word operations, typ.  | 2 ns  |
| for fixed point arithmetic, typ.   | 2 ns  |
| for floating point arithmetic, typ.  | 6 ns  |
| <b>CPU-blocks</b>  |   |
| Number of elements (total)   | 20 000; Blocks (OB, FB, FC, DB) and UDTs  |
| <b>DB</b>  |   |
| <ul style="list-style-type: none"> <li>Number range</li> <li>Size, max.</li> </ul>   | 1 ... 60 999; subdivided into: number range that can be used by the user: 1 ... 59 999, and number range of DBs created via SFC 86: 60 000 ... 60 999<br>16 Mbyte; For DBs with absolute addressing, the max. size is 64 KB |
| <b>FB</b>  |   |
| <ul style="list-style-type: none"> <li>Number range</li> <li>Size, max.</li> </ul>   | 0 ... 65 535<br>1 Mbyte   |
| <b>FC</b>  |   |
| <ul style="list-style-type: none"> <li>Number range</li> <li>Size, max.</li> </ul>   | 0 ... 65 535<br>1 Mbyte   |
| <b>OB</b>  |   |
| <ul style="list-style-type: none"> <li>Size, max.</li> <li>Number of free cycle OBs</li> <li>Number of time alarm OBs</li> <li>Number of delay alarm OBs</li> <li>Number of cyclic interrupt OBs</li> <li>Number of process alarm OBs</li> <li>Number of DPV1 alarm OBs</li> <li>Number of isochronous mode OBs</li> <li>Number of technology synchronous alarm OBs</li> <li>Number of startup OBs</li> <li>Number of asynchronous error OBs</li> <li>Number of synchronous error OBs</li> <li>Number of diagnostic alarm OBs</li> </ul> | 1 Mbyte<br>100<br>20<br>20<br>20; with minimum OB 3x cycle of 100 µs<br>50<br>3<br>3<br>2<br>100<br>4<br>2<br>1   |
| <b>Nesting depth</b>   |   |
| <ul style="list-style-type: none"> <li>per priority class</li> </ul>   | 24  |
| <b>Counters, timers and their retentivity</b>  |   |
| <b>S7 counter</b>  |   |
| <ul style="list-style-type: none"> <li>Number</li> </ul>   | 2 048   |
| Retentivity  |   |
| — adjustable   | Yes   |
| <b>IEC counter</b>   |   |
| <ul style="list-style-type: none"> <li>Number</li> </ul>   | Any (only limited by the main memory)   |
| Retentivity  |   |
| — adjustable   | Yes   |
| <b>S7 times</b>  |   |
| <ul style="list-style-type: none"> <li>Number</li> </ul>   | 2 048   |
| Retentivity  |   |
| — adjustable   | Yes   |
| <b>IEC timer</b>   |   |
| <ul style="list-style-type: none"> <li>Number</li> </ul>   | Any (only limited by the main memory)   |
| Retentivity  |   |
| — adjustable   | Yes   |

| Data areas and their retentivity   |   |
|--|---|
| Retentive data area (incl. timers, counters, flags), max.  | 768 kbyte; In total; available retentive memory for bit memories, timers, counters, DBs, and technology data (axes): 700 KB   |
| Extended retentive data area (incl. timers, counters, flags), max.   | 20 Mbyte; When using PS 6 0W 24/48/60 V DC HF   |
| Flag   |   |
| <ul style="list-style-type: none"> <li>• Size, max.</li> <li>• Number of clock memories</li> </ul>   | 16 kbyte<br>8; 8 clock memory bit, grouped into one clock memory byte   |
| Data blocks  |   |
| <ul style="list-style-type: none"> <li>• Retentivity adjustable</li> <li>• Retentivity preset</li> </ul>   | Yes<br>No   |
| Local data   |   |
| <ul style="list-style-type: none"> <li>• per priority class, max.</li> </ul>   | 64 kbyte; max. 16 KB per block  |
| Address area   |   |
| Number of IO modules   | 16 384; max. number of modules / submodules   |
| I/O address area   |   |
| <ul style="list-style-type: none"> <li>• Inputs</li> <li>• Outputs</li> </ul>  | 32 kbyte; All inputs are in the process image<br>32 kbyte; All outputs are in the process image   |
| per integrated IO subsystem  |   |
| — Inputs (volume)  | 32 kbyte; max. 32 KB via X1; max. 8 KB via X2 or X4   |
| — Outputs (volume)   | 32 kbyte; max. 32 KB via X1; max. 8 KB via X2 or X4   |
| per CM/CP  |   |
| — Inputs (volume)  | 8 kbyte   |
| — Outputs (volume)   | 8 kbyte   |
| Subprocess images  |   |
| <ul style="list-style-type: none"> <li>• Number of subprocess images, max.</li> </ul>  | 32  |
| Hardware configuration   |   |
| Number of distributed IO systems   | 64; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link) |
| Number of DP masters   |   |
| <ul style="list-style-type: none"> <li>• integrated</li> <li>• Via CM</li> </ul>   | 1<br>8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total  |
| Number of IO Controllers   |   |
| <ul style="list-style-type: none"> <li>• integrated</li> <li>• Via CM</li> </ul>   | 2<br>8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total  |
| Rack   |   |
| <ul style="list-style-type: none"> <li>• Modules per rack, max.</li> <li>• Number of lines, max.</li> </ul>  | 32; CPU + 31 modules<br>1   |
| PtP CM   |   |
| <ul style="list-style-type: none"> <li>• Number of PtP CMs</li> </ul>  | the number of connectable PtP CMs is only limited by the number of available slots  |
| Time of day  |   |
| Clock  |   |
| <ul style="list-style-type: none"> <li>• Type</li> <li>• Backup time</li> <li>• Deviation per day, max.</li> </ul>   | Hardware clock<br>6 wk; At 40 °C ambient temperature, typically<br>10 s; Typ.: 2 s  |
| Operating hours counter  |   |
| <ul style="list-style-type: none"> <li>• Number</li> </ul>   | 16  |
| Clock synchronization  |   |
| <ul style="list-style-type: none"> <li>• supported</li> <li>• to DP, master</li> <li>• in AS, master</li> <li>• in AS, slave</li> <li>• on Ethernet via NTP</li> </ul> | Yes<br>Yes<br>Yes<br>Yes<br>Yes   |
| Interfaces   |   |
| Number of PROFINET interfaces  | 3   |
| Number of PROFIBUS interfaces  | 1   |
| 1. Interface   |   |
| Interface types  |   |
| <ul style="list-style-type: none"> <li>• RJ 45 (Ethernet)</li> </ul>   | Yes; X1   |

|   |  |
|---|--|
| • Number of ports   | 2  |
| • integrated switch   | Yes  |
| <b>Protocols</b>  |  |
| • IP protocol   | Yes; IPv4  |
| • PROFINET IO Controller  | Yes  |
| • PROFINET IO Device  | Yes  |
| • SIMATIC communication   | Yes  |
| • Open IE communication   | Yes; Optionally also encrypted   |
| • Web server  | Yes  |
| • Media redundancy  | Yes  |
| <b>PROFINET IO Controller</b>   |  |
| <b>Services</b>   |  |
| — PG/OP communication   | Yes  |
| — Isochronous mode  | Yes  |
| — Direct data exchange  | Yes; Requirement: IRT and isochronous mode (MRPD optional)   |
| — IRT   | Yes  |
| — PROFINergy  | Yes; per user program  |
| — Prioritized startup   | Yes; Max. 32 PROFINET devices  |
| — Number of connectable IO Devices, max.                                      | 512; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET   |
| — Of which IO devices with IRT, max.  | 64   |
| — Number of connectable IO Devices for RT, max.                               | 512  |
| — of which in line, max.  | 512  |
| — Number of IO Devices that can be simultaneously activated/deactivated, max. | 8; in total across all interfaces  |
| — Number of IO Devices per tool, max.   | 8  |
| — Updating times  | The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data |
| <b>Update time for IRT</b>  |  |
| — for send cycle of 125 µs  | 125 µs   |
| — for send cycle of 187.5 µs  | 187.5 µs   |
| — for send cycle of 250 µs  | 250 µs to 4 ms   |
| — for send cycle of 500 µs  | 500 µs to 8 ms   |
| — for send cycle of 1 ms  | 1 ms to 16 ms  |
| — for send cycle of 2 ms  | 2 ms to 32 ms  |
| — for send cycle of 4 ms  | 4 ms to 64 ms  |
| — With IRT and parameterization of "odd" send cycles                          | Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs ... 3 875 µs)   |
| <b>Update time for RT</b>   |  |
| — for send cycle of 250 µs  | 250 µs to 128 ms   |
| — for send cycle of 500 µs  | 500 µs to 256 ms   |
| — for send cycle of 1 ms  | 1 ms to 512 ms   |
| — for send cycle of 2 ms  | 2 ms to 512 ms   |
| — for send cycle of 4 ms  | 4 ms to 512 ms   |
| <b>PROFINET IO Device</b>   |  |
| <b>Services</b>   |  |
| — PG/OP communication   | Yes  |
| — Isochronous mode  | No   |
| — IRT   | Yes; Minimum send cycle of 250 µs  |
| — PROFINergy  | Yes; per user program  |
| — Shared device   | Yes  |
| — Number of IO Controllers with shared device, max.                           | 4  |
| — activation/deactivation of I-devices  | Yes; per user program  |
| — Asset management record   | Yes; per user program  |
| <b>2. Interface</b>   |  |
| <b>Interface types</b>  |  |
| • RJ 45 (Ethernet)  | Yes; X2  |
| • Number of ports   | 1  |
| • integrated switch   | No   |
| <b>Protocols</b>  |  |
| • IP protocol   | Yes; IPv4  |

|   |  |
|---|--|
| • PROFINET IO Controller  | Yes  |
| • PROFINET IO Device  | Yes  |
| • SIMATIC communication   | Yes  |
| • Open IE communication   | Yes; Optionally also encrypted   |
| • Web server  | Yes  |
| • Media redundancy  | No   |
| <b>PROFINET IO Controller</b>   |  |
| <b>Services</b>   |  |
| — PG/OP communication   | Yes  |
| — Isochronous mode  | No   |
| — Direct data exchange  | No   |
| — IRT   | No   |
| — PROFlenergy   | Yes; per user program  |
| — Prioritized startup   | No   |
| — Number of connectable IO Devices, max.                                      | 128; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET   |
| — Number of connectable IO Devices for RT, max.                               | 128  |
| — of which in line, max.  | 128  |
| — Number of IO Devices that can be simultaneously activated/deactivated, max. | 8; in total across all interfaces  |
| — Number of IO Devices per tool, max.   | 8  |
| — Updating times  | The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data |
| <b>Update time for RT</b>   |  |
| — for send cycle of 1 ms  | 1 ms to 512 ms   |
| <b>PROFINET IO Device</b>   |  |
| <b>Services</b>   |  |
| — PG/OP communication   | Yes  |
| — Isochronous mode  | No   |
| — IRT   | No   |
| — PROFlenergy   | Yes; per user program  |
| — Prioritized startup   | No   |
| — Shared device   | Yes  |
| — Number of IO Controllers with shared device, max.                           | 4  |
| — activation/deactivation of I-devices  | Yes; per user program  |
| — Asset management record   | Yes; per user program  |
| <b>3. Interface</b>   |  |
| <b>Interface types</b>  |  |
| • RJ 45 (Ethernet)  | Yes; X3  |
| • Number of ports   | 1; C/C++ Runtime can also be reached via this port   |
| • integrated switch   | No   |
| <b>Protocols</b>  |  |
| • IP protocol   | Yes; IPv4  |
| • PROFINET IO Controller  | No   |
| • PROFINET IO Device  | No   |
| • SIMATIC communication   | Yes  |
| • Open IE communication   | Yes  |
| • Web server  | Yes  |
| <b>4. Interface</b>   |  |
| <b>Interface types</b>  |  |
| • RS 485  | Yes; X4  |
| • Number of ports   | 1  |
| <b>Protocols</b>  |  |
| • PROFIBUS DP master  | Yes  |
| • PROFIBUS DP slave   | No   |
| • SIMATIC communication   | Yes  |
| <b>PROFIBUS DP master</b>   |  |
| • Number of connections, max.   | 48; for the integrated PROFIBUS DP interface   |
| • Number of DP slaves, max.   | 125; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET   |
| <b>Services</b>   |  |

|   |  |
|---|--|
| — PG/OP communication                             | Yes  |
| — Equidistance                                    | Yes  |
| — Isochronous mode                                | Yes  |
| — Activation/deactivation of DP slaves            | Yes  |
| <b>Interface types</b>                            |  |
| <b>RJ 45 (Ethernet)</b>                           |  |
| • 100 Mbps  | Yes  |
| • 1000 Mbps                                       | Yes; Only possible at the X3 interface of the CPU 1518                             |
| • Autonegotiation                                 | Yes  |
| • Autocrossing                                    | Yes  |
| • Industrial Ethernet status LED                  | Yes  |
| <b>RS 485</b>                                     |  |
| • Transmission rate, max.                         | 12 Mbit/s  |
| <b>Protocols</b>                                  |  |
| PROFIsafe   | No   |
| <b>Number of connections</b>                      |  |
| • Number of connections, max.                     | 384; via integrated interfaces of the CPU and connected CPs / CMs                  |
| • Number of connections reserved for ES/HMI/web   | 10   |
| • Number of connections via integrated interfaces | 320  |
| • Number of S7 routing paths                      | 64; in total, only 16 S7-Routing connections are supported via PROFIBUS            |
| <b>Redundancy mode</b>                            |  |
| • H-Sync forwarding                               | Yes  |
| <b>Media redundancy</b>                           |  |
| — Media redundancy                                | only via 1st interface (X1)  |
| — MRP   | Yes; MRP Automanager according to IEC 62439-2 Edition 2.0, MRP Manager; MRP Client |
| — MRP interconnection, supported                  | Yes; as MRP ring node according to IEC 62439-2 Edition 3.0                         |
| — MRPD  | Yes; Requirement: IRT  |
| — Switchover time on line break, typ.             | 200 ms; For MRP, bumpless for MRPD   |
| — Number of stations in the ring, max.            | 50   |
| <b>SIMATIC communication</b>                      |  |
| • PG/OP communication                             | Yes; encryption with TLS V1.3 pre-selected   |
| • S7 routing                                      | Yes  |
| • Data record routing                             | Yes  |
| • S7 communication, as server                     | Yes  |
| • S7 communication, as client                     | Yes  |
| • User data per job, max.                         | See online help (S7 communication, user data size)                                 |
| <b>Open IE communication</b>                      |  |
| • TCP/IP  | Yes  |
| — Data length, max.                               | 64 kbyte   |
| — several passive connections per port, supported | Yes  |
| • ISO-on-TCP (RFC1006)                            | Yes  |
| — Data length, max.                               | 64 kbyte   |
| • UDP   | Yes  |
| — Data length, max.                               | 2 kbyte; 1 472 bytes for UDP broadcast   |
| — UDP multicast                                   | Yes; 128 multicast circuits (of which max. 5 via X1)                               |
| • DHCP  | Yes  |
| • DNS   | Yes  |
| • SNMP  | Yes; disconnected by default   |
| • DCP   | Yes  |
| • LLDP  | Yes  |
| • Encryption                                      | Yes; Optional  |
| <b>Web server</b>                                 |  |
| • HTTP  | Yes; Standard and user pages   |
| • HTTPS   | Yes; Standard and user pages   |
| <b>OPC UA</b>                                     |  |
| • Runtime license required                        | Yes; "Large" license required  |
| • OPC UA Client                                   | Yes; Data Access (registered Read/Write), Method Call                              |
| — Application authentication                      | Yes  |
| — Security policies                               | Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256    |

|  |  |
|--|--|
| — User authentication  | "anonymous" or by user name & password   |
| — Number of connections, max.  | 40   |
| — Number of nodes of the client interfaces, recommended max.   | 5 000  |
| — Number of elements for one call of OPC-UA_NodeGetHandleList/OPC-UA_ReadList/OPC-UA_WriteList, max.   | 300  |
| — Number of elements for one call of OPC-UA_NameSpaceGetIndexList, max.                                | 20   |
| — Number of elements for one call of OPC-UA_MethodGetHandleList, max.                                  | 100  |
| — Number of simultaneous calls of the client instructions for session management, per connection, max. | 1  |
| — Number of simultaneous calls of the client instructions for data access, per connection, max.        | 5  |
| — Number of registerable nodes, max.   | 5 000  |
| — Number of registerable method calls of OPC-UA_MethodCall, max.                                       | 100  |
| — Number of inputs/outputs when calling OPC-UA_MethodCall, max.  | 20   |
| ● OPC UA Server  | Yes; Data Access (Read, Write, Subscribe), Method Call, Alarms & Condition (A&C), Custom Address Space                   |
| — Application authentication   | Yes  |
| — Security policies  | available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256, Aes128Sha256RsaOaep, Aes256Sha256RsaPss |
| — User authentication  | "anonymous" or by user name & password   |
| — GDS support (certificate management)   | Yes  |
| — Number of sessions, max.   | 64   |
| — Number of accessible variables, max.   | 200 000  |
| — Number of registerable nodes, max.   | 50 000   |
| — Number of subscriptions per session, max.  | 50   |
| — Sampling interval, min.  | 10 ms  |
| — Publishing interval, min.  | 10 ms  |
| — Number of server methods, max.   | 100  |
| — Number of inputs/outputs per server method, max.   | 20   |
| — Number of monitored items, recommended max.  | 24 000; for 1 s sampling interval and 1 s send interval  |
| — Number of server interfaces, max.  | 10 of each "Server interfaces" / "Companion specification" type and 20 of the type "Reference namespace"                 |
| — Number of nodes for user-defined server interfaces, max.   | 30 000   |
| ● Alarms and Conditions  | Yes  |
| — Number of program alarms   | 400  |
| — Number of alarms for system diagnostics  | 200  |
| <b>Further protocols</b>   |  |
| ● MODBUS   | Yes; MODBUS TCP  |
| <b>Isochronous mode</b>  |  |
| Equidistance   | Yes  |
| <b>S7 message functions</b>  |  |
| Number of login stations for message functions, max.   | 64   |
| Program alarms   | Yes  |
| Number of configurable program messages, max.  | 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH                                    |
| Number of loadable program messages in RUN, max.   | 5 000  |
| Number of simultaneously active program alarms   |  |
| ● Number of program alarms   | 4 000  |
| ● Number of alarms for system diagnostics  | 1 000  |
| ● Number of alarms for motion technology objects   | 480  |
| <b>Test commissioning functions</b>  |  |
| Joint commission (Team Engineering)  | Yes; Parallel online access possible for up to 10 engineering systems  |
| Status block   | Yes; Up to 16 simultaneously (in total across all ES clients)  |
| Single step  | No   |
| Number of breakpoints  | 20   |
| <b>Status/control</b>  |  |
| ● Status/control variable  | Yes  |

|  |  |
|--|--|
| <ul style="list-style-type: none"> <li>• Variables</li> <li>• Number of variables, max. <ul style="list-style-type: none"> <li>— of which status variables, max.</li> <li>— of which control variables, max.</li> </ul> </li> </ul>  | Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters<br><br>200; per job<br>200; per job   |
| <b>Forcing</b>   |  |
| <ul style="list-style-type: none"> <li>• Forcing</li> <li>• Forcing, variables</li> <li>• Number of variables, max.</li> </ul>   | Yes<br>Peripheral inputs/outputs<br>200  |
| <b>Diagnostic buffer</b>   |  |
| <ul style="list-style-type: none"> <li>• present</li> <li>• Number of entries, max. <ul style="list-style-type: none"> <li>— of which powerfail-proof</li> </ul> </li> </ul>   | Yes<br>3 200<br>1 000  |
| <b>Traces</b>  |  |
| <ul style="list-style-type: none"> <li>• Number of configurable Traces</li> </ul>  | 8; Up to 512 KB of data per trace are possible   |
| <b>Interrupts/diagnostics/status information</b>   |  |
| <b>Diagnostics indication LED</b>  |  |
| <ul style="list-style-type: none"> <li>• RUN/STOP LED</li> <li>• ERROR LED</li> <li>• MAINT LED</li> <li>• Connection display LINK TX/RX</li> </ul>  | Yes<br>Yes<br>Yes<br>Yes   |
| <b>Supported technology objects</b>  |  |
| Motion Control <ul style="list-style-type: none"> <li>• Number of available Motion Control resources for technology objects</li> <li>• Required Motion Control resources <ul style="list-style-type: none"> <li>— per speed-controlled axis</li> <li>— per positioning axis</li> <li>— per synchronous axis</li> <li>— per external encoder</li> <li>— per output cam</li> <li>— per cam track</li> <li>— per probe</li> </ul> </li> <li>• Positioning axis <ul style="list-style-type: none"> <li>— Number of positioning axes at motion control cycle of 4 ms (typical value)</li> <li>— Number of positioning axes at motion control cycle of 8 ms (typical value)</li> </ul> </li> </ul> | Yes; Note: The number of technology objects affects the cycle time of the PLC program; selection guide via the TIA Selection Tool<br><br>15 360<br><br>40<br>80<br>160<br>80<br>20<br>160<br>40<br><br>140<br>192            |
| Controller <ul style="list-style-type: none"> <li>• PID_Compact</li> <li>• PID_3Step</li> <li>• PID-Temp</li> </ul>  | Yes; Universal PID controller with integrated optimization<br>Yes; PID controller with integrated optimization for valves<br>Yes; PID controller with integrated optimization for temperature                                |
| Counting and measuring <ul style="list-style-type: none"> <li>• High-speed counter</li> </ul>  | Yes  |
| <b>Ambient conditions</b>  |  |
| <b>Ambient temperature during operation</b>  |  |
| <ul style="list-style-type: none"> <li>• horizontal installation, min.</li> <li>• horizontal installation, max.</li> <li>• vertical installation, min.</li> <li>• vertical installation, max.</li> </ul>   | 0 °C<br>60 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the display is switched off<br><br>0 °C<br>40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off |
| <b>Ambient temperature during storage/transportation</b>   |  |
| <ul style="list-style-type: none"> <li>• min.</li> <li>• max.</li> </ul>   | -40 °C<br>70 °C  |
| <b>Altitude during operation relating to sea level</b>   |  |
| <ul style="list-style-type: none"> <li>• Installation altitude above sea level, max.</li> </ul>  | 5 000 m; Restrictions for installation altitudes > 2 000 m, see manual   |
| <b>configuration / header</b>  |  |
| <b>configuration / programming / header</b>  |  |
| Programming language <ul style="list-style-type: none"> <li>— LAD</li> <li>— FBD</li> </ul>  | Yes<br>Yes   |



|   |                               |
|---|-------------------------------|
| — STL   | Yes                           |
| — SCL   | Yes                           |
| — CFC   | Yes                           |
| — GRAPH   | Yes                           |
| <b>Know-how protection</b>                          |                               |
| • User program protection/password protection       | Yes                           |
| • Copy protection                                   | Yes                           |
| • Block protection                                  | Yes                           |
| <b>Access protection</b>                            |                               |
| • protection of confidential configuration data     | Yes                           |
| • Password for display                              | Yes                           |
| • Protection level: Write protection                | Yes                           |
| • Protection level: Read/write protection           | Yes                           |
| • Protection level: Complete protection             | Yes                           |
| <b>programming / cycle time monitoring / header</b> |                               |
| • lower limit                                       | adjustable minimum cycle time |
| • upper limit                                       | adjustable maximum cycle time |
| <b>Open Development interfaces</b>                  |                               |
| • Size of ODK SO file, max.                         | 9.8 Mbyte                     |
| <b>Dimensions</b>                                   |                               |
| Width   | 175 mm                        |
| Height  | 147 mm                        |
| Depth   | 129 mm                        |
| <b>Weights</b>                                      |                               |
| Weight, approx.                                     | 2 093 g                       |

**last modified:** 8/16/2023 